



Janice K. Brewer
Governor

ARIZONA DEPARTMENT OF ENVIRONMENTAL QUALITY

1110 West Washington Street • Phoenix, Arizona 85007
(602) 771-2300 • www.azdeq.gov



Henry R. Darwin
Acting Director

NOTICE OF PROPOSED ACTION by the

Arizona Department of Environmental Quality (ADEQ) on an application for an Arizona Pollutant Discharge Elimination System (AZPDES) Permit to discharge pollutants to Waters of the United States. ADEQ is issuing this notice of proposed action under the Clean Water Act (CWA) and in accordance with Arizona Administrative Code (A.A.C.) R18-9-A907.

The Director proposes to issue an AZPDES permit to discharge to the following applicant, subject to certain effluent limitations and special conditions:

Public Notice No. 07-09AZ

Publication Date: 5/6/09

AZPDES Permit No. AZ0025097
Weiner Development
520 Post Oak Blvd., Suite 850
Houston, TX 77027

The applicant applied for a renewal AZPDES permit for the discharge of up to 0.02 million gallons per day (mgd) of effluent from a wastewater treatment plant (WWTP) that serves the Cobre Valley Plaza Shopping Center in Claypool, Arizona. Effluent is discharged to Russell Gulch, tributary to Miami Wash in the Salt River Basin, in Gila County. The point of discharge is T1N, R15E, Section 21. Wastewater is domestic in nature, with no industrial component. This facility is an extended aeration package plant. Treatment processes consist of activated sludge biological treatment, solids settling in a secondary clarifier, chlorination followed by dechlorination. Sludge will be disposed of at an approved landfill. Pursuant to A.A.C. 18-11 Article 1, Appendix B, effluent limitations in the permit are based on the designated uses of aquatic and wildlife (effluent dependent water) (A&Wedw) and partial body contact (PBC). Effluent will be monitored for biochemical oxygen demand (BOD), total suspended solids (TSS), *E. coli*, oil and grease, total residual chlorine (TRC), pH, metals, cyanide and sulfides. Chronic whole effluent toxicity (WET) testing will be required once in year four of the permit to assist in determining whether synergistic effects of monitored or non-monitored parameters are occurring.

With 24 hour notice, the draft permit and related documentation is available for public review Monday through Friday from 8:30 a.m. to 4:30 p.m. at the ADEQ Phoenix office. To review the file, contact the Records Management Center, 24 hours in advance at (602) 771- 4380. A copy of the pertinent documents may also be obtained by calling or writing ADEQ as follows.

Persons may submit comments or request a public hearing on the proposed action, in writing, to:

Ramona Chomor
Arizona Department of Environmental Quality
Water Quality Division
1110 W. Washington – 5415A-1
Phoenix, AZ 85007
Telephone: 602-771-4515

Northern Regional Office
1801 West Route 66 • Suite 117 • Flagstaff, AZ 86001
(928) 779-0313

Southern Regional Office
400 West Congress Street • Suite 433 • Tucson, AZ 85701
(520) 628-6733

All written comments received by ADEQ by the close of business on the date 30 days after publication of this notice will be considered in the final permit decision. Requests for a hearing must be in writing and must state the issues proposed to be raised in a hearing. If there is a significant degree of public interest, the Director will hold a hearing in accordance with A.A.C. R18-9-908(B). Additional notice of such hearing would be published at least 30 days prior to the hearing date.

Please bring the foregoing notice to the attention of all persons you know would be interested in this matter.