

STATE OF ARIZONA
AQUIFER PROTECTION PERMIT NO. P-100665
PLACE ID 12694, LTF 43614
SIGNIFICANT AMENDMENT

1.0 AUTHORIZATION

In compliance with the provisions of Arizona Revised Statutes (A.R.S.) Title 49, Chapter 2, Articles 1, 2 and 3, Arizona Administrative Code (A.A.C.) Title 18, Chapter 9, Articles 1 and 2, A.A.C. Title 18, Chapter 11, Article 4 and amendments thereto, and the conditions set forth in this permit, the City of Coolidge is hereby authorized to operate the City of Coolidge Wastewater Treatment Plant, located in Coolidge, Arizona, in Pinal County, over groundwater of the Pinal Active Management Area, in Township 5 S, Range 8 E, Section 29 of the Gila and Salt River Baseline and Meridian.

This permit becomes effective on the date of the Water Quality Division Director's signature and shall be valid for the life of the facility (operational, closure, and post-closure periods) unless suspended or revoked pursuant to A.A.C. R18-9-A213. The permittee shall construct, operate and maintain the permitted facilities:

1. Following all the conditions of this permit including the design and operational information documented or referenced below, and
2. Such that Aquifer Water Quality Standards (AWQS) are not violated at the applicable point(s) of compliance (POC) set forth below or if an AWQS for a pollutant has been exceeded in an aquifer at the time of permit issuance, that no additional degradation of the aquifer relative to that pollutant and as determined at the applicable POC occurs as a result of the discharge from the facility.

1.1 PERMITTEE INFORMATION

Facility Name: City of Coolidge Wastewater Treatment Plant
Facility Address: 802 S Kenworthy Rd
Coolidge, Arizona 85228
Pinal County

Permittee: City of Coolidge
Permittee Address: 355 S 1st St
Coolidge, Arizona 85228

Facility Contact: Don Peters, Public Works Director
Emergency Phone No.: (520) 723-4882

Latitude/Longitude: 32° 58' 10" N/ 111° 32' 47" W
Legal Description: Township 05S, Range 08E, Section 29, NE ¼ of the Gila and Salt River Baseline and Meridian

1.2 AUTHORIZING SIGNATURE

Henry Darwin, Acting Director
Water Quality Division
Arizona Department of Environmental Quality

Signed this ____ day of _____, 2009

THIS AMENDED PERMIT SUPERCEDES ALL PREVIOUS PERMITS

2.0 SPECIFIC CONDITIONS [A.R.S. §§ 49-203(4), 49-241(A)]

2.1 Facility / Site Description [A.R.S. § 49-243(K)(8)]

The permittee is authorized to operate the City of Coolidge Wastewater Treatment Plant at a flow rate of 1.0 million gallons per day (mgd) during Phase I of the permit, and 2.0 mgd during Phase II. Incoming wastewater flows through an influent pump station to a headworks with a magnetic flow meter, then to 4 treatment lagoons (3A, 3B, 2B, and 1B) connected in series. The effluent from the treatment ponds will be chlorinated and stored in two storage ponds with a capacity of 18.2 million gallons, prior to distribution for beneficial reuse.

The WWTP will produce reclaimed water meeting Class C Reclaimed Water Standards (A.A.C. R18-11, Article 3) that may be delivered for beneficial use under a valid reclaimed water permit under A.A.C. R18-9, Article 7.

The WWTP has the capacity to collect and treat a maximum average monthly flow of 2.0 million gallons per day (mgd) of domestic wastewater. The 370 acre reuse site can accept 1.0 mgd of reclaimed water. Therefore, the permitted flow limit during Phase I is 1.0 mgd (Section 4.2, Table IA-1). Once additional acreage is added to increase the reclaimed water capacity to a total of 2.0 mgd, and ADEQ issues an amended reclaimed water permit, this permit will enter Phase II (Section 3.0, Compliance Schedule and Section 4.2, Table IA-2), with a permitted flow limit of 2.0 mgd.

Sludge shall be land applied on a permitted sludge disposal area, or hauled to a state-approved landfill for management and disposal. Screenings and grit shall be hauled to a state-approved landfill for management and disposal. In addition to the APP conditions pertaining to treatment and disposal of sewage sludge, the permittee must also comply with the requirements for sewage sludge disposal, use, and transportation in 40 Code of Federal Regulations (CFR) Part 503 and 18 A.A.C. 9, Article 10.

The depth to groundwater is approximately 60 feet below the surface, and the direction of groundwater flow is toward the northwest. The WWTP was designed, constructed, and located according to plans approved by the Arizona Department of Health Services.

All industrial hookups and other non-residential hookups to the treatment system shall be authorized according to the applicable federal, state or local regulations.

The site includes the following permitted discharging facilities:

Facility	Latitude	Longitude
City of Coolidge WWTP	32° 58' 10" N	111° 32' 47" W ¹

Amendment Description

The purpose of this amendment is to make room for the first phase of construction of a new mechanical Water Reclamation Facility, to be built in the same location as the current lagoons. The facility currently treats wastewater using six treatment lagoons (1A, 1B, 2A, 2B, 3A, 3B) connected in parallel. Under this permit Lagoons 1A and 2A will be removed from service, the remaining lagoons (3A, 3B, 2B, and 1B) will be connected in series, rather than parallel operation, and the aeration system will be upgraded. Lagoons 1A and 2A are to be closed under a closure plan, as per Section 3.0. After lagoons 1A & 2A are closed, a 2.0 mgd mechanical plant will be constructed in the footprint of the closed lagoons under APP No. P-105911. Phase I of this amendment sets the permitted flow limit to 1.0 mgd, and Phase II sets the permitted flow limit to 2.0 mgd. This permit amendment also changes the frequency of monitoring for Fecal Coliform and Volatile

¹ All latitudes and longitudes in this permit are listed in NAD83.

Organic Compounds (VOCs) in Section 4.2, Table IA-1 and IA-2. In addition, relevant permit language has been changed to conform to the current APP format.

Annual Registration Fee [A.R.S. § 49-242]

The Annual Registration Fee for this permit is established by A.R.S. § 49-242(E) and is payable to the Arizona Department of Environmental Quality (ADEQ) each year. The design flow is 2.0 mgd.

Financial Capability [A.R.S. § 49-243(N) and A.A.C. R18-9-A203]

The permittee has demonstrated financial capability under A.R.S. § 49-243(N) and A.A.C. R18-9-A203. The permittee shall maintain financial capability throughout the life of the facility. The estimated dollar amount demonstrated for financial capability is \$450,000.00.

2.2 Best Available Demonstrated Control Technology [A.R.S. § 49-243(B) and A.A.C. R18-9-A202(A)(5)]

The Water Reclamation Facility shall be designed, constructed, operated, and maintained to meet the treatment performance criteria for existing facilities as specified in A.A.C. R18-9-B205.

The facility shall meet the requirements for pretreatment by conducting monitoring as per A.A.C. R18-9-B204(B)(6)(b)(iii).

2.2.1 Engineering Design

The WWTP was designed as per the design report prepared and stamped, dated, and signed (sealed) by Dr. Fred E. Goldman, Ph.D., Kennedy/Jenks Consultants, AZ Registered Professional Engineer (Civil) No. 11580, dated December 03, 2004 and subsequent sealed submittals that served as additions to the design report.

2.2.2 Site-specific Characteristics

Not applicable at the time of permit issuance.

2.2.3 Pre-operational Requirements

Not applicable at the time of permit issuance.

2.2.4 Operational Requirements

1. Permittee shall maintain a copy of the Operations and Maintenance Manual at the WWTP site at all times, which shall be available upon request during inspections by ADEQ personnel.
2. The pollution control structures shall be inspected for the items listed in Section 4.2, Table III.
3. If any damage of the pollution control structures is identified during inspection, proper repair procedures shall be performed. All repair procedures and material(s) used shall be documented on the Self-Monitoring Report Form submitted quarterly to the ADEQ Water Quality Compliance Section.

2.2.5 Reclaimed Water Classification

[A.A.C. R18-9-703(C)(2)(a), A.A.C. R18-11-303 through 307]

The treatment facility is classified as producing Class C reclaimed water and may be used for any allowable Class C use under a valid reclaimed water permit.

2.2.6 Certified Area wide Water Quality Management Plan Conformance
[A.A.C. R18-9-A201(B)(6)(a)]

Facility operations must conform to the approved Certified Areawide Water Quality Management Plan according to the 208 consistency determination in place at the time of permit issuance.

2.3 Discharge Limitations [A.R.S. §§ 49-201(14), 49-243 and A.A.C. R18-9-A205(B)]

1. The permittee is authorized to operate the WWTP with a maximum average monthly flow of 1.0 mgd during Phase I, and 2.0 mgd during Phase II.
2. The permittee shall notify all users that the materials authorized to be disposed of through the WRF are typical household sewage and pre-treated commercial wastewater and shall not include motor oil, gasoline, paints, varnishes, hazardous wastes, solvents, pesticides, fertilizers or other materials not generally associated with toilet flushing, food preparation, laundry facilities and personal hygiene.
3. The permittee shall operate and maintain all permitted facilities to prevent unauthorized discharges pursuant to A.R.S. § 49-201(12) resulting from failure or bypassing of applicable BADCT pollutant control technologies including liner failure², uncontrollable leakage, overtopping (e.g., exceeding the maximum storage capacity, defined as a fluid level exceeding the crest elevation of a permitted impoundment), of basins, lagoons, impoundments or sludge drying beds, berm breaches, accidental spills, or other unauthorized discharges.
4. Specific discharge limitations are listed in Section 4.2, Tables IA-1, IA-2 and IB.

2.4 Points of Compliance (POCs) [A.R.S. § 49-244]

The POCs are established by the following designated locations:

POC #	Location	Latitude	Longitude
1	Approximately 1,370 feet east of Lagoon 1B	32° 58' 15" N	111° 32' 28" W
2	Approximately 250 feet northwest of Lagoon 2A.	32° 58' 16" N	111° 32' 48" W

Groundwater monitoring is not required at POC #1, except as a contingency action. Groundwater monitoring is required at POC #2. Initial groundwater monitoring will be conducted to determine Alert Levels (ALs) and Aquifer Quality Limits (AQLs), followed by routine monitoring.

The Director may amend this permit to require installation of wells and initiation of groundwater monitoring at the POC or to designate additional points of compliance if information on groundwater gradients or groundwater usage indicates the need.

2.5 Monitoring Requirements [A.R.S. § 49-243(K)(1), A.A.C. R18-9-A206(A)]

All monitoring required in this permit shall continue for the duration of the permit, regardless of the status of the facility. All sampling, preservation and holding times shall be in accordance with currently accepted standards of professional practice. Trip blanks, equipment blanks and duplicate samples shall also be obtained, and Chain-of-Custody procedures shall be followed, in accordance with currently accepted standards of professional practice. The permittee shall consult the most recent version of the ADEQ Quality Assurance Project Plan (QAPP) and Environmental Protection Agency (EPA) 40 Code of Federal

²Liner failure in a single-lined impoundment is any condition that would result in leakage exceeding 550 gallons per day per acre.

Regulations (CFR) PART 136 for guidance in this regard. Copies of laboratory analyses and Chain-of-Custody forms shall be maintained at the permitted facility. Upon request these documents shall be made immediately available for review by ADEQ personnel.

2.5.1 Pre-Operational Monitoring

Not applicable at the time of permit issuance.

2.5.2 Routine Discharge Monitoring

The permittee shall monitor the wastewater according to Section 4.2, Tables IA-1 and IA-2. Representative samples of the wastewater shall be collected at the point of discharge from the chlorine contact chamber.

2.5.3. Reclaimed Water Monitoring

The permittee shall monitor the reclaimed water parameters listed under Section 4.2, Table IB in addition to the routine discharge monitoring parameters listed in Section 4.2, Tables IA-1 and IA-2. Representative samples of the reclaimed water shall be collected at the point of discharge from the chlorine contact chamber.

2.5.4 Facility / Operational Monitoring

Operational monitoring inspections shall be conducted according to Section 4.2, Table III.

1. If any damage of the pollution control structures is identified during inspection, proper repair procedures shall be performed. All repair procedures and materials used shall be documented on the SMRF submitted quarterly to the ADEQ Water Quality Compliance Section, Data Unit. If none of the conditions occur, the report shall say "no event" for a particular reporting period. If the facility is not in operation, the permittee shall indicate this on the SMRF.
2. The permittee shall submit data required in Section 4.2, Table III regardless of the operating status of the facility unless otherwise approved by the Department or allowed in this permit.

2.5.5 Groundwater Monitoring and Sampling Protocols

Routine groundwater monitoring is required as per Section 4.2, Tables IIA and IIB. Static water levels shall be measured and recorded prior to sampling. Wells shall be purged of at least three borehole volumes (as calculated using the static water level) or until field parameters (pH, temperature, conductivity) are stable, whichever represents the greater volume. If evacuation results in the well going dry, the well shall be allowed to recover to 80 percent (%) of the original borehole volume, or for 24 hours, whichever is shorter, prior to sampling. If after 24 hours there is not sufficient water for sampling, the well shall be recorded as "dry" for the monitoring event. An explanation for reduced pumping volumes, a record of the volume pumped, and modified sampling procedures shall be reported and submitted with the SMRF.

2.5.6 Surface Water Monitoring and Sampling Protocols

Routine surface water monitoring is not required under the terms of this permit.

2.5.7 Analytical Methodology

All samples collected for compliance monitoring shall be analyzed using Arizona state approved methods. If no state approved method exists, then any appropriate EPA-approved method shall be used. Regardless of the method used, the detection limits must be sufficient to determine compliance with the regulatory limits of the parameters specified in this permit. Analyses shall be performed by a laboratory

licensed by the Arizona Department of Health Services, Office of Laboratory Licensure and Certification. For results to be considered valid, all analytical work shall meet quality control standards specified in the approved methods. A list of Arizona state certified laboratories can be obtained at the address below:

Arizona Department of Health Services
Office of Laboratory Licensure and Certification
250 North 17th Ave.
Phoenix, AZ 85007
Phone: (602) 364-0720

2.5.8 Installation and Maintenance of Monitoring Equipment

Monitoring equipment required by this permit shall be installed and maintained so that representative samples required by the permit can be collected. If new groundwater wells are determined to be necessary, the construction details shall be submitted to the ADEQ Groundwater Section for approval prior to installation and the permit shall be amended to include any new monitoring points.

2.6 Contingency Plan Requirements

[A.R.S. § 49-243(K)(3), (K)(7) and A.A.C. R18-9-A204 and R18-9-A205]

2.6.1 General Contingency Plan Requirements

At least one copy of the approved contingency and emergency response plan(s) submitted in the application shall be maintained at the location where day-to-day decisions regarding the operation of the facility are made. The permittee shall be aware of and follow the contingency and emergency plans.

Any AL exceedance, violation of a discharge limit (DL), AQL, or other permit condition shall be reported to ADEQ following the reporting requirements in Section 2.7.3.

Some contingency actions involve verification sampling. Verification sampling shall consist of the first follow-up sample collected from a location that previously indicated a violation or the exceedance of an AL. Collection and analysis of the verification sample shall use the same protocols and test methods to analyze for the pollutant or pollutants that exceeded an AL or violated an AQL. The permittee is subject to enforcement action for the failure to comply with any contingency actions in this permit. Where verification sampling is specified in this permit, it is the option of the permittee to perform such sampling. If verification sampling is not conducted within the timeframe allotted, ADEQ and the permittee shall presume the initial sampling result to be confirmed as if verification sampling has been conducted. The permittee is responsible for compliance with contingency plans relating to the exceedance of an AL or violation of a DL, AQL, or any other permit condition.

2.6.2 Exceeding of Alert Levels/Performance Levels

2.6.2.1 Exceeding of Performance Levels Set for Operational Conditions

1. If an operational performance level (PL) set in Section 4.2, Table III has been exceeded the permittee shall:
 - b. Notify the ADEQ Water Quality Compliance Section within five days of becoming aware of the exceedance.
 - c. Submit a written report within 30 days after becoming aware of the exceedance. The report shall document all of the following:

- (1) A description of the exceedance and its cause;
 - (2) the period of the exceedance, including exact date(s) and time(s), if known, and the anticipated time period during which the exceedance is expected to continue;
 - (3) any action taken or planned to mitigate the effects of the exceedance or spill, or to eliminate or prevent recurrence of the exceedance or spill;
 - (4) any monitoring activity or other information which indicates that any pollutants would be reasonably expected to cause a violation of an AWQS; and
 - (5) any malfunction or failure of pollution control devices or other equipment or process.
2. The facility is no longer on alert status once the operational indicator no longer indicates that a PL is being exceeded. The permittee shall, however, complete all tasks necessary to return the facility to its pre-alert operating condition.

2.6.2.2 Exceeding of Alert Levels (ALs) Set for Discharge Monitoring

1. If an AL set in Section 4.2, Tables IA-1 and IA-2 has been exceeded, the permittee shall immediately investigate to determine the cause. The investigation shall include the following:
 - a. Inspection, testing, and assessment of the current condition of all treatment or pollutant discharge control systems that may have contributed to the exceedance;
 - b. Review of recent process logs, reports, and other operational control information to identify any unusual occurrences; and
 - c. If the investigation procedures indicated in (a) and (b) above fail to reveal the cause of the exceedance, the permittee shall sample individual waste streams composing the wastewater for the parameters in question, if necessary to identify the cause of the exceedance.
2. The permittee shall initiate actions identified in the approved contingency plan referenced in Section 5.0 and specific contingency measures identified in Section 2.6 to resolve any problems identified by the investigation which may have led to an AL exceedance. To implement any other corrective action the permittee shall obtain prior approval from ADEQ according to Section 2.6.6.
3. Within 30 days of an AL exceedance, the permittee shall submit the laboratory results to the ADEQ Water Quality Compliance Section, Data Unit, along with a summary of the findings of the investigation, the cause of the exceedance, and actions taken to resolve the problem.
4. Upon review of the submitted report, the Department may amend the permit to require additional monitoring, increased frequency of monitoring, amendments to permit conditions or other actions.

2.6.2.2.1 Exceeding Permit Flow Limit

1. If the AL for average monthly flow in Section 4.2, Tables IA-1 and IA-2 has been exceeded, the permittee shall submit an application for an APP amendment to expand the WRF or submit a report detailing the reasons that expansion is not necessary.
2. Acceptance of the report instead of an application for expansion requires ADEQ approval.

2.6.2.3 Exceeding of Alert Levels in Groundwater Monitoring

2.6.2.3.1 Alert Levels for Indicator Parameters

No ALs were established for indicator parameters.

2.6.2.3.2 Alert Levels for Pollutants with Numeric Aquifer Water Quality Standards

1. If an AL for a pollutant set in Section 4.2, Tables IIA and IIB has been exceeded, the permittee may conduct verification sampling within five days of becoming aware of the exceedance. The permittee may use results of another sample taken between the date of the last sampling event and the date of receiving the result as verification.
2. If verification sampling confirms the AL exceedance or if the permittee opts not to perform verification sampling, then the permittee shall increase the frequency of monitoring as follows:

Specified Monitoring Frequency (Section 4.2, Tables IIA and IIB)	Monitoring Frequency for AL Exceedance
Daily	Daily
Weekly	Daily
Monthly	Weekly
Quarterly	Monthly
Semi-annually	Quarterly
Annually	Quarterly

In addition, the permittee shall immediately initiate an investigation of the cause of the AL exceedance, including inspection of all discharging units and all related pollution control devices, review of any operational and maintenance practices that might have resulted in an unexpected discharge, and hydrologic review of groundwater conditions including upgradient water quality.

3. The permittee shall initiate actions identified in the approved contingency plan referenced in Part 5.0 and specific contingency measures identified in Part 2.6 to resolve any problems identified by the investigation which may have led to an AL exceedance. To implement any other corrective action the permittee shall obtain prior approval from ADEQ according to Section 2.6.6. Alternatively, the permittee may submit a technical demonstration, subject to written approval by the Groundwater Section, that although an AL is exceeded, pollutants are not reasonably expected to cause a violation of an AQL. The demonstration may propose a revised AL or monitoring frequency for approval in writing by the Groundwater Section.
4. Within 30 days after confirmation of an AL exceedance, the permittee shall submit the laboratory results to the Water Quality Compliance Section along with a summary of the findings of the investigation, the cause of the exceedance, and actions taken to resolve the problem.
5. Upon review of the submitted report, the Department may amend the permit to require additional monitoring, increased frequency of monitoring, amendments to permit conditions or other actions.
6. The increased monitoring required as a result of an AL exceedance may be reduced to the monitoring frequency in Section 4.2, Tables IIA and IIB if the results of four sequential sampling events demonstrate that no parameters exceed the AL.

7. If the increased monitoring required as a result of an AL exceedance continues for more than six sequential sampling events, the permittee shall submit a second report documenting an investigation of the continued AL exceedance within 30 days of the receipt of laboratory results of the sixth sampling event.

2.6.2.3.3 Alert Levels to Protect Downgradient Users from Pollutants Without Numeric Aquifer Water Quality Standards

Not required at time of permit issuance.

2.6.3 Discharge Limit Violation

1. If a DL set in Section 4.2, Tables IA-1, IA-2 or IB has been violated, the permittee shall immediately investigate to determine the cause of the violation. The investigation shall include the following:
 - a. Inspection, testing, and assessment of the current condition of all treatment or pollutant discharge control systems that may have contributed to the violation;
 - b. Review of recent process logs, reports, and other operational control information to identify any unusual occurrences; and
 - c. If the investigation procedures indicated in (a) and (b) above fail to reveal the cause of the violation, the permittee shall sample individual waste streams composing the wastewater for the parameters in violation, if necessary to identify the cause of the violation.

The permittee also shall submit a report according to Section 2.7.3, which includes a summary of the findings of the investigation, the cause of the violation, and actions taken to resolve the problem. The permittee shall consider and ADEQ may require corrective action that may include control of the source of discharge, cleanup of affected soil, surface water or groundwater, and mitigation of the impact of pollutants on existing uses of the aquifer. Corrective actions shall either be specifically identified in this permit, included in an ADEQ approved contingency plan, or separately approved according to Section 2.6.6.

2. The permittee shall comply with the freeboard requirements as specified in Section 4.2, Table III (Facility Inspections) to prevent the overtopping of an impoundment or sludge drying bed. If an impoundment or sludge drying bed is overtopped, the permittee shall follow the requirements in Section 2.6.5.3 and the reporting requirements of Section 2.7.3.
3. Upon review of the submitted report, the Department may amend the permit to require additional monitoring, increased frequency of monitoring, amendments to permit conditions, or other actions.

2.6.4 Aquifer Quality Limit Violation

1. If an AQL set in Section 4.2, Tables IIA and IIB has been exceeded, the permittee may conduct verification sampling within five days of becoming aware of an AQL being exceeded. The permittee may use results of another sample taken between the date of the last sampling event and the date of receiving the result as verification.
2. If the verification sample does not confirm an AQL violation, no further action is needed under this Section.
3. If verification sampling confirms that the AQL is violated for any parameter or if the permittee opts not to perform verification sampling, then, the permittee shall increase the frequency of monitoring as follows:

Specified Monitoring Frequency (Section 4.2, Tables IIA and IIB)	Monitoring Frequency for AQL Exceedance
Daily	Daily
Weekly	Daily
Monthly	Weekly
Quarterly	Monthly
Semi-annually	Quarterly
Annually	Quarterly

In addition, the permittee shall immediately initiate an evaluation for the cause of the violation, including inspection of all discharging units and all related pollution control devices, and review of any operational and maintenance practices that might have resulted in unexpected discharge.

The permittee also shall submit a report according to Section 2.7.3, which includes a summary of the findings of the investigation, the cause of the violation, and actions taken to resolve the problem. A verified exceedance of an AQL will be considered a violation unless the permittee demonstrates within 30 days that the exceedance was not caused or contributed to by pollutants discharged from the facility. Unless the permittee has demonstrated that the exceedance was not caused or contributed to by pollutants discharged from the facility, the permittee shall consider and ADEQ may require corrective action that may include control of the source of discharge, cleanup of affected soil, surface water or groundwater, and mitigation of the impact of pollutants on existing uses of the aquifer. Corrective actions shall either be specifically identified in this permit, included in an ADEQ approved contingency plan, or separately approved according to Section 2.6.6.

4. Upon review of the submitted report, the Department may amend the permit to require additional monitoring, increased frequency of monitoring, amendments to permit conditions or other actions.

2.6.5 Emergency Response and Contingency Requirements for Unauthorized Discharges pursuant to A.R.S. § 49-201(12) and pursuant to A.R.S. § 49-241

2.6.5.1 Duty to Respond

The permittee shall act immediately to correct any condition resulting from a discharge pursuant to A.R.S. § 49-201(12) if that condition could pose an imminent and substantial endangerment to public health or the environment.

2.6.5.2 Discharge of Hazardous Substances or Toxic Pollutants

In the event of any unauthorized discharge pursuant to A.R.S. § 49-201(12) of suspected hazardous substances (A.R.S. § 49-201(19)) or toxic pollutants (A.R.S. § 49-243(I)) on the facility site, the permittee shall promptly isolate the area and attempt to identify the discharged material. The permittee shall record information, including name, nature of exposure and follow-up medical treatment, if necessary, on persons who may have been exposed during the incident. The permittee shall notify the ADEQ Water Quality Compliance Section at (602) 771-4497 within 24 hours of discovering the discharge of hazardous material which: a) has the potential to cause an AWQS or AQL exceedance, or; b) could pose an endangerment to public health or the environment.

2.6.5.3 Discharge of Non-hazardous Materials

In the event of any unauthorized discharge pursuant to A.R.S. § 49-201(12) of non-hazardous materials from the facility, the permittee shall promptly attempt to cease the discharge and isolate the discharged material. Discharged material shall be removed and the site cleaned up as soon as possible. The permittee shall notify and the ADEQ Water Quality Compliance Section at (602) 771-4497 within 24 hours of discovering the discharge of non-hazardous material which: a) has

the potential to cause an AQL exceedance, or; b) could pose an endangerment to public health or the environment.

2.6.5.4 Reporting Requirements

The permittee shall submit a written report for any unauthorized discharges reported under Sections 2.6.5.2 and 2.6.5.3 to the ADEQ Water Quality Compliance Section (see Section 2.7.5) within thirty days of the discharge or as required by subsequent ADEQ action. The report shall summarize the event, including any human exposure, and facility response activities and include all information specified in Section 2.7.3. If a notice is issued by ADEQ subsequent to the discharge notification, any additional information requested in the notice shall also be submitted within the time frame specified in the notice. Upon review of the submitted report, ADEQ may require additional monitoring or corrective actions.

2.6.6 Corrective Actions

Specific contingency measures identified in Section 2.6 have already been approved by ADEQ and do not require written approval to implement.

With the exception of emergency response actions taken under Section 2.6.5, the permittee shall obtain written approval from the Groundwater Section prior to implementing a corrective action to accomplish any of the following goals in response to exceedance of an AL or violation of an AQL, DL, or other permit condition:

1. Control of the source of an unauthorized discharge;
2. Soil cleanup;
3. Cleanup of affected surface waters;
4. Cleanup of affected parts of the aquifer; and/or
5. Mitigation to limit the impact of pollutants on existing uses of the aquifer.

Within 30 days of completion of any corrective action, the operator shall submit to the ADEQ Water Quality Compliance Section, a written report describing the causes, impacts, and actions taken to resolve the problem.

2.7 Reporting and Recordkeeping Requirements [A.R.S. § 49-243(K)(2) and A.A.C. R18-9-A206(B) and R18-9-A207]

2.7.1 Self-Monitoring Report Form

1. The permittee shall complete the SMRF provided by ADEQ. The completed SMRF shall be submitted to the Water Quality Compliance Section, Data Unit.
2. The permittee shall complete the SMRF to the extent that the information reported may be entered on the form. If no information is required during a quarter, the permittee shall enter "not required" on the SMRF and submit the report to ADEQ. The permittee shall use the format devised by ADEQ.
3. The tables contained in Section 4.0 list the parameters to be monitored and the frequency for reporting results for compliance monitoring. Monitoring and analytical methods shall be recorded on the SMRF. The permittee reserves the right to request a relaxation of the monitoring frequency for metals and volatile organic compounds through a permit amendment if the data indicate that water quality standards are being achieved consistently.
4. In addition to the SMRF, the information contained in A.A.C. R18-9-A206(B)(1) shall be included for exceeding an AL or violation of an AQL, DL, or any other permit condition being reported in the current reporting period.

2.7.2 Operation Inspection / Log Book Recordkeeping

A signed copy of this permit shall be maintained at all times at the location where day-to-day decisions regarding the operation of the facility are made. A log book (paper copies, forms, or electronic data) of the inspections and measurements required by this permit shall be maintained at the location where day-to-day decisions are made regarding the operation of the facility. The log book shall be retained for ten years from the date of each inspection, and upon request, the permit and the log book shall be made immediately available for review by ADEQ personnel. The information in the log book shall include, but not be limited to, the following information as applicable:

1. Name of inspector;
2. Date and shift inspection was conducted;
3. Condition of applicable facility components;
4. Any damage or malfunction, and the date and time any repairs were performed;
5. Documentation of sampling date and time; and
6. Any other information required by this permit to be entered in the log book.

Monitoring records for each measurement shall comply with R18-9-A206(B)(2).

2.7.3 Permit Violation and Alert Level Status Reporting

1. The permittee shall notify the Water Quality Compliance Section in writing (by mail or by fax - see Section 2.7.5) within five (5) days (except as provided in Section 2.6.5) of becoming aware of a violation of any permit condition, discharge limitation, or of an AL exceedance.
2. The permittee shall submit a written report to the Water Quality Compliance Section within 30 days of becoming aware of the violation of any permit condition or discharge limitation. The report shall document all of the following:
 - a. Identification and description of the permit condition for which there has been a violation and a description of the cause;
 - b. The period of violation including exact date(s) and time(s), if known, and the anticipated time period during which the violation is expected to continue;
 - c. Any corrective action taken or planned to mitigate the effects of the violation, or to eliminate or prevent a recurrence of the violation;
 - d. Any monitoring activity or other information which indicates that any pollutants would be reasonably expected to cause a violation of an AWQS;
 - e. Proposed changes to the monitoring which include changes in constituents or increased frequency of monitoring; and
 - f. Description of any malfunction or failure of pollution control devices or other equipment or processes.

2.7.4 Operational, Other or Miscellaneous Reporting

The permittee shall complete the SMRF provided by the Department to reflect facility inspection requirements designated in Section 4.2, Table III and submit to the ADEQ Water Quality Compliance Section, Data Unit quarterly along with other reports required by this permit. Facility inspection reports shall be submitted no less frequently than quarterly, regardless of operational status.

If the treatment facility is classified for reclaimed water under this permit, the permittee shall submit the reclaimed water monitoring results as required in Section 4.2, Table IB and flow volumes to any of the following in accordance with A.A.C. R18-9-703(C)(2)(c):

1. Any reclaimed water agent who has contracted for delivery of reclaimed water from the permittee; and
2. Any end user who has not waived interest in receiving this information.

2.7.5 Reporting Location

All SMRFs shall be submitted to:

Arizona Department of Environmental Quality
Water Quality Compliance Section, Data Unit
Mail Code 5415B-1
1110 West Washington Street
Phoenix, Arizona 85007
Phone (602) 771-4681

All documents required by this permit to be submitted to the Water Quality Compliance Section shall be directed to the following address:

Arizona Department of Environmental Quality
Water Quality Compliance Section
Mail Code 5415B-1
1110 West Washington Street
Phoenix, Arizona 85007
Phone (602) 771-4497
Fax (602) 771-4505

All documents required by this permit to be submitted to the Groundwater Section shall be directed to:

Arizona Department of Environmental Quality
Groundwater Section
Mail Code 5415B-3
1110 West Washington Street
Phoenix, Arizona 85007
Phone (602) 771-4428

2.7.6 Reporting Deadline

The following table lists the quarterly report due dates:

Monitoring conducted during quarter:	Quarterly Report due by:
January-March	April 30
April-June	July 30
July-September	October 30
October-December	January 30

The following table lists the semi-annual and annual report due dates:

Monitoring conducted:	Report due by:
Semi-annual: January-June	July 30
Semi-annual: July-December	January 30
Annual: January-December	January 30

2.7.7 Changes to Facility Information in Section 1.0

The Groundwater Section and Water Quality Compliance Section shall be notified within 10 days of any change of facility information including Facility Name, Permittee Name, Mailing or Street Address, Facility Contact Person, or Emergency Telephone Number.

2.8 Temporary Cessation [A.R.S. § 49-243(K)(8) and A.A.C. R18-9-A209(A)]

The permittee shall give written notice to the Water Quality Compliance Section before ceasing operation of the facility for a period of 60 days or greater. The permittee shall take the following measures upon temporary cessation:

1. If applicable, direct the wastewater flows from the facility to another state-approved wastewater treatment facility;
2. Correct the problem that caused the temporary cessation of the facility; and
3. Notify the ADEQ Water Quality Compliance Section with a monthly facility status report describing the activities conducted on the treatment facility to correct the problem.

At the time of notification the permittee shall submit for ADEQ approval a plan for maintenance of discharge control systems and for monitoring during the period of temporary cessation. Immediately following ADEQ approval, the permittee shall implement the approved plan. If necessary, ADEQ shall amend permit conditions to incorporate conditions to address temporary cessation. During the period of temporary cessation, the permittee shall provide written notice to the Water Quality Compliance Section of the operational status of the facility every three years. If the permittee intends to permanently cease operation of any facility, the permittee shall submit closure notification, as set forth in Section 2.9 below.

2.9 Closure [A.R.S. §§ 49-243(K)(6), 49-252 and A.A.C. R18-9-A209(B)]

For a facility addressed under this permit, the permittee shall give written notice of closure to the Water Quality Compliance Section of the intent to cease operation without resuming activity for which the facility was designed or operated.

2.9.1 Closure Plan

Within 90 days following notification of closure, the permittee shall submit for approval to the Groundwater Section, a closure plan which meets the requirements of A.R.S. § 49-252 and A.A.C. R18-9-A209(B)(3).

If the closure plan achieves clean closure immediately, ADEQ shall issue a letter of approval to the permittee. If the closure plan contains a schedule for bringing the facility to a clean closure configuration at a future date, ADEQ may incorporate any part of the schedule as an amendment to this permit.

2.9.2 Closure Completion

Upon completion of closure activities, the permittee shall give written notice to the Groundwater Section indicating that the approved closure plan has been implemented fully and providing supporting documentation to demonstrate that clean closure has been achieved (soil sample results, verification sampling results, groundwater data, as applicable). If clean closure has been achieved, ADEQ shall issue a letter of approval to the permittee at that time. If any of the following conditions apply, the permittee shall follow the terms of post-closure stated in this permit:

1. Clean closure cannot be achieved at the time of closure notification or within one year thereafter under a diligent schedule of closure actions;

2. Further action is necessary to keep the facility in compliance with AWQS at the applicable POC;
3. Continued action is required to verify that the closure design has eliminated discharge to the extent intended;
4. Remedial or mitigation measures are necessary to achieve compliance with Title 49, Ch. 2; and
5. Further action is necessary to meet property use restrictions.

2.10 Post-closure [A.R.S. §§ 49-243(K)(6), 49-252 and A.A.C. R18-9 A209(C)]

Post-closure requirements shall be established based on a review of facility closure actions and will be subject to review and approval by the Groundwater Section.

In the event clean-closure cannot be achieved pursuant to A.R.S. § 49-252, the permittee shall submit for approval to the Groundwater Section a post-closure plan that addresses post-closure maintenance and monitoring actions at the facility. The post-closure plan shall meet all requirements of A.R.S. §§ 49-201(30) and 49-252 and A.A.C. R18-9-A209(C). Upon approval of the post-closure plan, this permit shall be amended or a new permit shall be issued to incorporate all post-closure controls and monitoring activities of the post-closure plan.

2.10.1 Post-closure Plan

A specific post-closure plan may be required upon the review of the closure plan.

2.10.2 Post-closure Completion

Not required at the time of permit issuance.

3.0 COMPLIANCE SCHEDULE [A.R.S. § 49-243(K)(5) and A.A.C. R18-9-A208]

For each compliance schedule item listed below, the permittee shall submit the required information, including a cover letter that lists the compliance schedule items, to the Groundwater Section. A copy of the cover letter must also be submitted to the ADEQ Water Quality Compliance Section.

Description	Due by:
<p>3.1 The permittee shall submit for ADEQ approval a closure plan for lagoons 1A and 2A that complies with the requirements of Arizona Revised Statute (A.R.S.) § 49-252(D) and A.A.C. R18-9-A209(B) and (C). The plan shall include a description of the methodologies and procedures to be used to provide the following:</p> <ul style="list-style-type: none"> a. Descriptions and photographs of each of the liners, showing their condition upon removal, b. The depth of visibly impacted soils. c. After the sludge and impacted soils are removed, the City shall collect confirmation soil samples from below the liner to insure that no soils remain that have pollutant concentrations above applicable GPLs and SRLs. Sludge and soil shall be tested for the pollutants in permit Table I. d. A photographic log of the closure activities, to be submitted to the Groundwater Section. e. A report of the volume of sludge and impacted soils removed from each lagoon. f. A characterization of the sludge and impacted soils removed from each lagoon, providing “cradle to grave” waste disposal documentation. If any material is taken away for disposal, documentation shall be provided. g. Contingency plans to be followed if the results of the soil samples are above SRLs or GPLs. 	<p>Within 30 days after the date of permit signature.</p>
<p>3.2 The permittee shall install a groundwater monitoring well at POC #2 according to ADEQ approved plans.</p>	<p>Within 30 days after the date of permit signature.</p>
<p>3.3 The permittee shall submit detailed geologic and well construction logs for the well at POC #2 to the ADEQ Groundwater Section, APP & Drywell Unit. Where identification is possible, the logs should note moisture and the depth at which groundwater is first encountered. The ADWR Registry ID (55 No.) shall be submitted to ADEQ.</p>	<p>Within 60 days after completion of well installation.</p>
<p>3.4 The permittee shall conduct initial groundwater sampling at POC #2 in accordance with AAC R18-9-A202(A)(6) and Section 4.2, Table IIA.</p>	<p>Within 30 days after completion of well construction.</p>
<p>3.5 The permittee shall submit an APP Amendment Application with a report of the test results and propose ALs & AQLs for POC #2 for all the pollutants listed in Section 4.2, Table IIA in accordance with A.A.C. R18-9-A202(A)(6) and A.A.C. R18-9-A205.</p>	<p>Within 15 months after the date of permit signature.</p>
<p>3.6 The permittee shall begin routine depth-to-water (DTW) measurements from ADWR Registered Well # 55-591694, located adjacent to the chlorine contact basin. Frequency shall be monthly for 1 year, then quarterly thereafter.</p>	<p>Within 30 days after the date of permit signature.</p>

Description	Due by:
3.7 The permittee shall cease monitoring under Section 4.2, Table IA-1 and begin monitoring under Table IA-2.	Within 30 days after the signature date of a reclaimed water permit allowing a total of 2.0 mgd of reclaimed water to be delivered.

4.0 TABLES OF MONITORING REQUIREMENTS

4.1 PRE-OPERATIONAL MONITORING (OR CONSTRUCTION REQUIREMENTS)

Not applicable at the time of permit issuance.

4.0 TABLES OF MONITORING REQUIREMENTS

4.2 COMPLIANCE (or OPERATIONAL) MONITORING

**TABLE IA-1 (Phase I – flows up to 1.0 mgd)³
ROUTINE DISCHARGE MONITORING**

Sampling Point Number	Sampling Point Identification			Latitude	Longitude
1	Discharge from the chlorine contact chamber			32° 58' 07" N	111° 32' 43" W
Parameter	AL ⁴	DL ⁵	Units	Sampling Frequency	Reporting Frequency
Total Flow ⁶ : Daily ⁷	Not Established ⁸	Not Established	mgd ⁹	Daily	Quarterly
Total Flow: Monthly Average ¹⁰	0.95	1.0	mgd	Monthly Calculation	Quarterly
Total Flow - Reuse Daily	Not Established	Not Established	mgd	Daily	Quarterly
Total Flow - Reuse Monthly Daily Average ¹¹	Not Established	1.0	mgd	Monthly Calculation	Quarterly
Fecal Coliform: Single sample maximum	Not Established	4,000	CFU or MPN ¹²	Monthly	Quarterly
Fecal Coliform: four (4) of seven (7) samples in a week ¹³	Not Established	1,000 ¹⁴	CFU or MPN	Monthly	Quarterly
Total Nitrogen ¹⁵ : Five-sample rolling geometric mean	Not Established	Not Established	mg/l	Monthly ¹⁶	Quarterly

³Monitoring for Phase I is no longer required after signature of a reclaimed water permit allowing delivery of a total of 2.0 mgd of water, as per the Compliance Schedule, Section 3.0.

⁴AL = Alert Level

⁵DL = Discharge Limit

⁶Total flow for all methods of disposal

⁷Flow shall be measured using a continuous recording flow meter which totals the flow daily.

⁸Not Established means monitoring is required but no limits are specified.

⁹mgd = million gallons per day

¹⁰Monthly average of daily flow values.

¹¹Monthly average of daily flow values.

¹²CFU = Colony Forming Units / 100 ml sample. MPN = Most Probable Number / 100 ml sample. For CFU, a value of <1.0 shall be considered to be non-detect. For MPN, a value of <2.2 shall be considered to be non-detect.

¹³**Week** means a seven-day period starting on Sunday and ending on the following Saturday.

¹⁴If at least four (4) of seven (7) samples in a week are less than 1000, report “yes” in the appropriate space on the SMRF (indicating that the standard has been met). If at least four (4) of seven (7) samples in a week have detections of fecal coliform at 1000 cfu or more, report “no” in the appropriate space on the SMRF (indicating that the standard has **not** been met).

¹⁵Total Nitrogen = Nitrate as N + Nitrite as N + Total Kjeldahl Nitrogen

¹⁶A five-month geometric mean of the results of the five (5) most recent samples

4.2 COMPLIANCE (or OPERATIONAL) MONITORING

**TABLE IA-1 (Phase I – flows up to 1.0 mgd)
ROUTINE DISCHARGE MONITORING (continued)**

Parameter	AL	DL	Units	Sampling Frequency	Reporting Frequency
Metals (total):					
Antimony	0.0048	0.006	mg/l	Quarterly	Quarterly
Arsenic	0.04	0.05	mg/l	Quarterly	Quarterly
Barium	1.60	2.00	mg/l	Quarterly	Quarterly
Beryllium	0.0032	0.004	mg/l	Quarterly	Quarterly
Cadmium	0.004	0.005	mg/l	Quarterly	Quarterly
Chromium	0.08	0.1	mg/l	Quarterly	Quarterly
Cyanide (as free cyanide)	0.16	0.2	mg/l	Quarterly	Quarterly
Fluoride	3.2	4.0	mg/l	Quarterly	Quarterly
Lead	0.04	0.05	mg/l	Quarterly	Quarterly
Mercury	0.0016	0.002	mg/l	Quarterly	Quarterly
Nickel	0.08	0.1	mg/l	Quarterly	Quarterly
Selenium	0.04	0.05	mg/l	Quarterly	Quarterly
Thallium	0.0016	0.002	mg/l	Quarterly	Quarterly

4.2 COMPLIANCE (or OPERATIONAL) MONITORING

**TABLE IA-1 (Phase I – flows up to 1.0 mgd)
ROUTINE DISCHARGE MONITORING (continued)**

Parameter	AL	DL	Units	Sampling Frequency	Reporting Frequency
Volatile Organic Compounds (VOCs):					
Benzene	0.004	0.005	Mg/l	Semi-Annually	Semi-Annually
Carbon tetrachloride	0.004	0.005	Mg/l	Semi-Annually	Semi-Annually
o-Dichlorobenzene	0.48	0.6	Mg/l	Semi-Annually	Semi-Annually
para-Dichlorobenzene	0.06	0.075	Mg/l	Semi-Annually	Semi-Annually
1,2-Dichloroethane	0.004	0.005	Mg/l	Semi-Annually	Semi-Annually
1,1-Dichloroethylene	0.0056	0.007	Mg/l	Semi-Annually	Semi-Annually
cis-1,2-Dichloroethylene	0.056	0.07	Mg/l	Semi-Annually	Semi-Annually
trans-1,2-Dichloroethylene	0.08	0.1	Mg/l	Semi-Annually	Semi-Annually
Dichloromethane	0.004	0.005	Mg/l	Semi-Annually	Semi-Annually
1,2-Dichloropropane	0.004	0.005	Mg/l	Semi-Annually	Semi-Annually
Ethylbenzene	0.56	0.7	Mg/l	Semi-Annually	Semi-Annually
Hexachlorobenzene	0.0008	0.001	Mg/l	Semi-Annually	Semi-Annually
Hexachlorocyclopentadiene	0.04	0.05	Mg/l	Semi-Annually	Semi-Annually
Monochlorobenzene	0.08	0.1	Mg/l	Semi-Annually	Semi-Annually
Styrene	0.08	0.1	Mg/l	Semi-Annually	Semi-Annually
Tetrachloroethylene	0.004	0.005	Mg/l	Semi-Annually	Semi-Annually
Toluene	0.8	1.0	Mg/l	Semi-Annually	Semi-Annually
Trihalomethanes (total) ¹⁷	0.08	0.1	Mg/l	Semi-Annually	Semi-Annually
1,1,1-Trichloroethane	0.16	0.2	Mg/l	Semi-Annually	Semi-Annually
1,2,4 - Trichlorobenzene	0.056	0.07	Mg/l	Semi-Annually	Semi-Annually
1,1,2 - Trichloroethane	0.004	0.005	Mg/l	Semi-Annually	Semi-Annually
Trichloroethylene	0.004	0.005	Mg/l	Semi-Annually	Semi-Annually
Vinyl Chloride	0.0016	0.002	Mg/l	Semi-Annually	Semi-Annually
Xylenes (Total)	8.0	10.0	Mg/l	Semi-Annually	Semi-Annually

¹⁷Total Trihalomethanes are comprised of Bromoform, Bromodichloromethane, Chloroform, and Dibromochloromethane.

4.2 COMPLIANCE (or OPERATIONAL) MONITORING

**TABLE IA-1 (Phase I – flows up to 1.0 mgd)
ROUTINE DISCHARGE MONITORING (continued)**

Parameter	AL	DL	Units	Sampling Frequency	Reporting Frequency
Indicator Parameters / Major Cations and Anions:					
pH (field)	Monitor ¹⁸	Monitor	S.U.	Quarterly	Quarterly
Iron	Monitor	Monitor	mg/l	Quarterly	Quarterly
Manganese	Monitor	Monitor	mg/l	Quarterly	Quarterly
Total Organic Carbon	Monitor	Monitor	mg/l	Quarterly	Quarterly
Total Dissolved Solids	Monitor	Monitor	mg/l	Quarterly	Quarterly
Sodium	Monitor	Monitor	mg/l	Quarterly	Quarterly
Potassium	Monitor	Monitor	mg/l	Quarterly	Quarterly
Calcium	Monitor	Monitor	mg/l	Quarterly	Quarterly
Magnesium	Monitor	Monitor	mg/l	Quarterly	Quarterly
Chloride	Monitor	Monitor	mg/l	Quarterly	Quarterly
Sulfate	Monitor	Monitor	mg/l	Quarterly	Quarterly
Alkalinity	Monitor	Monitor	mg/l	Quarterly	Quarterly
Specific Conductivity (field)	Monitor	Monitor	µmhos/cm	Quarterly	Quarterly

¹⁸ Monitoring is required, but no limits have been established.

4.2 COMPLIANCE (or OPERATIONAL) MONITORING

**TABLE IA-2 (Phase II – flows up to 2.0 mgd)¹⁹
ROUTINE DISCHARGE MONITORING**

Sampling Point Number	Sampling Point Identification			Latitude	Longitude
1	Discharge from the chlorine contact chamber			32° 58' 07" N	111° 32' 43" W
Parameter	AL ²⁰	DL ²¹	Units	Sampling Frequency	Reporting Frequency
Total Flow ²² : Daily ²³	Not Established ²⁴	Not Established	mgd ²⁵	Daily	Quarterly
Total Flow: Monthly Average ²⁶	0.95	2.0	mgd	Monthly Calculation	Quarterly
Total Flow - Reuse Daily	Not Established	Not Established	mgd	Daily	Quarterly
Total Flow - Reuse Monthly Daily Average ²⁷	Not Established	2.0	mgd	Monthly Calculation	Quarterly
Fecal Coliform: Single sample maximum	Not Established	4,000	CFU or MPN ²⁸	Monthly	Quarterly
Fecal Coliform: four (4) of seven (7) samples in a week ²⁹	Not Established	1,000 ³⁰	CFU or MPN	Monthly	Quarterly
Total Nitrogen ³¹ : Five-sample rolling geometric mean	Not Established	Not Established	mg/l	Monthly ³²	Quarterly

¹⁹Monitoring for Phase I is no longer required after monitoring for Phase II begins.

²⁰ AL = Alert Level

²¹DL = Discharge Limit

²²Total flow for all methods of disposal

²³Flow shall be measured using a continuous recording flow meter which totals the flow daily.

²⁴Not Established means monitoring is required but no limits are specified.

²⁵mgd = million gallons per day

²⁶Monthly average of daily flow values.

²⁷Monthly average of daily flow values.

²⁸CFU = Colony Forming Units / 100 ml sample. MPN = Most Probable Number / 100 ml sample. For CFU, a value of <1.0 shall be considered to be non-detect. For MPN, a value of <2.2 shall be considered to be non-detect.

²⁹**Week** means a seven-day period starting on Sunday and ending on the following Saturday.

³⁰If at least four (4) of seven (7) samples in a week are less than 1000, report “yes” in the appropriate space on the SMRF (indicating that the standard has been met). If at least four (4) of seven (7) samples in a week have detections of fecal coliform at 1000 cfu or more, report “no” in the appropriate space on the SMRF (indicating that the standard has **not** been met).

³¹Total Nitrogen = Nitrate as N + Nitrite as N + Total Kjeldahl Nitrogen

³²A five-month geometric mean of the results of the five (5) most recent samples

4.2 COMPLIANCE (or OPERATIONAL) MONITORING

**TABLE IA-2 (Phase II – flows up to 2.0 mgd)
ROUTINE DISCHARGE MONITORING (continued)**

Parameter	AL	DL	Units	Sampling Frequency	Reporting Frequency
Metals (total):					
Antimony	0.0048	0.006	mg/l	Quarterly	Quarterly
Arsenic	0.04	0.05	mg/l	Quarterly	Quarterly
Barium	1.60	2.00	mg/l	Quarterly	Quarterly
Beryllium	0.0032	0.004	mg/l	Quarterly	Quarterly
Cadmium	0.004	0.005	mg/l	Quarterly	Quarterly
Chromium	0.08	0.1	mg/l	Quarterly	Quarterly
Cyanide (as free cyanide)	0.16	0.2	mg/l	Quarterly	Quarterly
Fluoride	3.2	4.0	mg/l	Quarterly	Quarterly
Lead	0.04	0.05	mg/l	Quarterly	Quarterly
Mercury	0.0016	0.002	mg/l	Quarterly	Quarterly
Nickel	0.08	0.1	mg/l	Quarterly	Quarterly
Selenium	0.04	0.05	mg/l	Quarterly	Quarterly
Thallium	0.0016	0.002	mg/l	Quarterly	Quarterly

4.2 COMPLIANCE (or OPERATIONAL) MONITORING

**TABLE IA-2 (Phase II – flows up to 2.0 mgd)
ROUTINE DISCHARGE MONITORING (continued)**

Parameter	AL	DL	Units	Sampling Frequency	Reporting Frequency
Volatile Organic Compounds (VOCs):					
Benzene	0.004	0.005	Mg/l	Semi-Annually	Semi-Annually
Carbon tetrachloride	0.004	0.005	Mg/l	Semi-Annually	Semi-Annually
o-Dichlorobenzene	0.48	0.6	Mg/l	Semi-Annually	Semi-Annually
para-Dichlorobenzene	0.06	0.075	Mg/l	Semi-Annually	Semi-Annually
1,2-Dichloroethane	0.004	0.005	Mg/l	Semi-Annually	Semi-Annually
1,1-Dichloroethylene	0.0056	0.007	Mg/l	Semi-Annually	Semi-Annually
cis-1,2-Dichloroethylene	0.056	0.07	Mg/l	Semi-Annually	Semi-Annually
trans-1,2-Dichloroethylene	0.08	0.1	Mg/l	Semi-Annually	Semi-Annually
Dichloromethane	0.004	0.005	Mg/l	Semi-Annually	Semi-Annually
1,2-Dichloropropane	0.004	0.005	Mg/l	Semi-Annually	Semi-Annually
Ethylbenzene	0.56	0.7	Mg/l	Semi-Annually	Semi-Annually
Hexachlorobenzene	0.0008	0.001	Mg/l	Semi-Annually	Semi-Annually
Hexachlorocyclopentadiene	0.04	0.05	Mg/l	Semi-Annually	Semi-Annually
Monochlorobenzene	0.08	0.1	Mg/l	Semi-Annually	Semi-Annually
Styrene	0.08	0.1	Mg/l	Semi-Annually	Semi-Annually
Tetrachloroethylene	0.004	0.005	Mg/l	Semi-Annually	Semi-Annually
Toluene	0.8	1.0	Mg/l	Semi-Annually	Semi-Annually
Trihalomethanes (total) ³³	0.08	0.1	Mg/l	Semi-Annually	Semi-Annually
1,1,1-Trichloroethane	0.16	0.2	Mg/l	Semi-Annually	Semi-Annually
1,2,4 - Trichlorobenzene	0.056	0.07	Mg/l	Semi-Annually	Semi-Annually
1,1,2 - Trichloroethane	0.004	0.005	Mg/l	Semi-Annually	Semi-Annually
Trichloroethylene	0.004	0.005	Mg/l	Semi-Annually	Semi-Annually
Vinyl Chloride	0.0016	0.002	Mg/l	Semi-Annually	Semi-Annually
Xylenes (Total)	8.0	10.0	Mg/l	Semi-Annually	Semi-Annually

³³Total Trihalomethanes are comprised of Bromoform, Bromodichloromethane, Chloroform, and Dibromochloromethane.

4.2 COMPLIANCE (or OPERATIONAL) MONITORING

**TABLE IA-2 (Phase II – flows up to 2.0 mgd)
ROUTINE DISCHARGE MONITORING (continued)**

Parameter	AL	DL	Units	Sampling Frequency	Reporting Frequency
Indicator Parameters / Major Cations and Anions:					
pH (field)	Monitor ³⁴	Monitor	S.U.	Quarterly	Quarterly
Iron	Monitor	Monitor	mg/l	Quarterly	Quarterly
Manganese	Monitor	Monitor	mg/l	Quarterly	Quarterly
Total Organic Carbon	Monitor	Monitor	mg/l	Quarterly	Quarterly
Total Dissolved Solids	Monitor	Monitor	mg/l	Quarterly	Quarterly
Sodium	Monitor	Monitor	mg/l	Quarterly	Quarterly
Potassium	Monitor	Monitor	mg/l	Quarterly	Quarterly
Calcium	Monitor	Monitor	mg/l	Quarterly	Quarterly
Magnesium	Monitor	Monitor	mg/l	Quarterly	Quarterly
Chloride	Monitor	Monitor	mg/l	Quarterly	Quarterly
Sulfate	Monitor	Monitor	mg/l	Quarterly	Quarterly
Alkalinity	Monitor	Monitor	mg/l	Quarterly	Quarterly
Specific Conductivity (field)	Monitor	Monitor	µmhos/cm	Quarterly	Quarterly

³⁴ Monitoring is required, but no limits have been established.

4.2 COMPLIANCE (or OPERATIONAL) MONITORING

RECLAIMED WATER MONITORING TABLE - CLASS C³⁵

Sampling Point Number	Sampling Point Identification		Latitude	Longitude
1	Discharge from the chlorine contact chamber		32° 58' 07" N	111° 32' 43" W
Parameter	DL	Units	Sampling Frequency	Reporting Frequency
Fecal Coliform: Single-sample maximum	4,000	CFU or MPN ³⁶	Monthly	Quarterly
Fecal Coliform: Four (4) of last seven (7) samples	1,000 ³⁷	CFU or MPN	Monthly	Quarterly

³⁵Reclaimed water monitoring under Table IB shall be performed in addition to routine discharge monitoring required under Section 4.2, Tables IA-1 and IA-2.

³⁶CFU = Colony Forming Units per 100 ml. MPN = Most Probable Number per 100 ml. For CFU, a value of <1.0 shall be considered to be non-detect. For MPN, a value of <2.2 shall be considered to be non-detect.

³⁷If at least four (4) of the last seven (7) samples are 1000 cfu or less, report "yes" in the appropriate space on the SMRF (indicating that the standard has been met). If at least four (4) of the last seven (7) samples have detections of fecal coliform of 1000 or more, report "no" in the appropriate space on the SMRF (indicating that the standard has **not** been met).

4.2 COMPLIANCE (or OPERATIONAL) MONITORING

**TABLE IIA
AMBIENT GROUNDWATER MONITORING**

Sampling Point Number	Sampling Point Identification			Latitude	Longitude
2	POC # 2			32° 58' 16" N	111° 32' 48" W
Parameter	AL ³⁸	AQL ³⁹	Units	Sampling Frequency	Reporting Frequency
Depth to water ⁴⁰	NE ⁴¹	NE	Feet below surface	Quarterly ⁴²	Quarterly
Total Nitrogen ⁴³ :	NE	NE	mg/l	Monthly	Quarterly
Nitrate-Nitrite as N	NE	NE	mg/l	Monthly	Quarterly
Total Kjeldahl Nitrogen (TKN)	NE	NE	mg/l	Monthly	Quarterly
Total Coliform	NE	NE	P/A ⁴⁴	Monthly	Quarterly
Metals (total):					
Antimony	NE	NE	mg/l	Quarterly	Quarterly
Arsenic	NE	NE	mg/l	Quarterly	Quarterly
Barium	NE	NE	mg/l	Quarterly	Quarterly
Beryllium	NE	NE	mg/l	Quarterly	Quarterly
Cadmium	NE	NE	mg/l	Quarterly	Quarterly
Chromium	NE	NE	mg/l	Quarterly	Quarterly
Cyanide (as free cyanide)	NE	NE	mg/l	Quarterly	Quarterly
Fluoride	NE	NE	mg/l	Quarterly	Quarterly
Lead	NE	NE	mg/l	Quarterly	Quarterly
Mercury	NE	NE	mg/l	Quarterly	Quarterly
Nickel	NE	NE	mg/l	Quarterly	Quarterly
Selenium	NE	NE	mg/l	Quarterly	Quarterly
Thallium	NE	NE	mg/l	Quarterly	Quarterly

³⁸ AL = Alert Level

³⁹ AQL = Aquifer Quality Limit

⁴⁰ To be determined based upon the completion of Section 3.5, Compliance Schedule.

⁴¹ NE = Not Established. Monitoring is required, but no limits are specified.

⁴² As per Section 3.6, Compliance Schedule, Frequency shall be Monthly for one year after the date of permit signature, then Quarterly thereafter

⁴³ Total Nitrogen is equal to nitrate as N plus nitrite as N plus TKN.

⁴⁴ P/A = Presence or absence of total coliform in a 100-milliliter sample.

4.2 COMPLIANCE (or OPERATIONAL) MONITORING

**TABLE IIA
AMBIENT GROUNDWATER MONITORING (continued)**

Parameter	AL	AQ	Units	Sampling Frequency	Reporting Frequency
Volatile Organic Compounds (VOCs):					
Benzene	NE	NE	mg/l	Semi-Annually	Semi-Annually
Carbon tetrachloride	NE	NE	mg/l	Semi-Annually	Semi-Annually
o-Dichlorobenzene	NE	NE	mg/l	Semi-Annually	Semi-Annually
para-Dichlorobenzene	NE	NE	mg/l	Semi-Annually	Semi-Annually
1,2-Dichloroethane	NE	NE	mg/l	Semi-Annually	Semi-Annually
1,1-Dichloroethylene	NE	NE	mg/l	Semi-Annually	Semi-Annually
cis-1,2-Dichloroethylene	NE	NE	mg/l	Semi-Annually	Semi-Annually
trans-1,2-Dichloroethylene	NE	NE	mg/l	Semi-Annually	Semi-Annually
Dichloromethane	NE	NE	mg/l	Semi-Annually	Semi-Annually
1,2-Dichloropropane	NE	NE	mg/l	Semi-Annually	Semi-Annually
Ethylbenzene	NE	NE	mg/l	Semi-Annually	Semi-Annually
Hexachlorobenzene	NE	NE	mg/l	Semi-Annually	Semi-Annually
Hexachlorocyclopentadiene	NE	NE	mg/l	Semi-Annually	Semi-Annually
Monochlorobenzene	NE	NE	mg/l	Semi-Annually	Semi-Annually
Styrene	NE	NE	mg/l	Semi-Annually	Semi-Annually
Tetrachloroethylene	NE	NE	mg/l	Semi-Annually	Semi-Annually
Toluene	NE	NE	mg/l	Semi-Annually	Semi-Annually
Trihalomethanes (total) ⁴⁵	NE	NE	mg/l	Semi-Annually	Semi-Annually
1,1,1-Trichloroethane	NE	NE	mg/l	Semi-Annually	Semi-Annually
1,2,4 - Trichlorobenzene	NE	NE	mg/l	Semi-Annually	Semi-Annually
1,1,2 - Trichloroethane	NE	NE	mg/l	Semi-Annually	Semi-Annually
Trichloroethylene	NE	NE	mg/l	Semi-Annually	Semi-Annually
Vinyl Chloride	NE	NE	mg/l	Semi-Annually	Semi-Annually
Xylenes (Total)	NE	NE	mg/l	Semi-Annually	Semi-Annually

⁴⁵Total Trihalomethanes are comprised of Bromoform, Bromodichloromethane, Chloroform, and Dibromochloromethane.

4.2 COMPLIANCE (or OPERATIONAL) MONITORING

**TABLE IIA
AMBIENT GROUNDWATER MONITORING (continued)**

Parameter	AL	AQL	Units	Sampling Frequency	Reporting Frequency
Indicator Parameters / Major Cations and Anions:					
pH (field)	Monitor ⁴⁶	Monitor	S.U.	Quarterly	Quarterly
Iron	Monitor	Monitor	mg/l	Quarterly	Quarterly
Manganese	Monitor	Monitor	mg/l	Quarterly	Quarterly
Total Organic Carbon	Monitor	Monitor	mg/l	Quarterly	Quarterly
Total Dissolved Solids	Monitor	Monitor	mg/l	Quarterly	Quarterly
Sodium	Monitor	Monitor	mg/l	Quarterly	Quarterly
Potassium	Monitor	Monitor	mg/l	Quarterly	Quarterly
Calcium	Monitor	Monitor	mg/l	Quarterly	Quarterly
Magnesium	Monitor	Monitor	mg/l	Quarterly	Quarterly
Chloride	Monitor	Monitor	mg/l	Quarterly	Quarterly
Sulfate	Monitor	Monitor	mg/l	Quarterly	Quarterly
Alkalinity	Monitor	Monitor	mg/l	Quarterly	Quarterly
Specific Conductivity (field)	Monitor	Monitor	µmhos/cm	Quarterly	Quarterly

⁴⁶ Monitoring is required, but no limits have been established.

4.2 COMPLIANCE (or OPERATIONAL) MONITORING

**TABLE IIB
ROUTINE GROUNDWATER MONITORING**

Sampling Point Number	Sampling Point Identification			Latitude	Longitude
2	POC # 2			32° 58' 16" N	111° 32' 48" W
Parameter	AL ⁴⁷	AQL ⁴⁸	Units	Sampling Frequency	Reporting Frequency
Depth to water ⁴⁹	NE ⁵⁰	NE	Feet below surface	Quarterly	Quarterly
Total Nitrogen ⁵¹ :	NE	NE	mg/l	Monthly	Quarterly
Nitrate-Nitrite as N	NE	NE	mg/l	Monthly	Quarterly
Total Kjeldahl Nitrogen (TKN)	NE	NE	mg/l	Monthly	Quarterly
Total Coliform	Absence	Absence	P/A ⁵²	Monthly	Quarterly
Metals (total):					
Antimony	0.0048	0.006	mg/l	Quarterly	Quarterly
Arsenic	0.30	0.05	mg/l	Quarterly	Quarterly
Barium	1.60	2.00	mg/l	Quarterly	Quarterly
Beryllium	0.0032	0.004	mg/l	Quarterly	Quarterly
Cadmium	0.004	0.005	mg/l	Quarterly	Quarterly
Chromium	0.15	0.1	mg/l	Quarterly	Quarterly
Cyanide (as free cyanide)	0.16	0.2	mg/l	Quarterly	Quarterly
Fluoride	3.2	4.0	mg/l	Quarterly	Quarterly
Lead	0.04	0.05	mg/l	Quarterly	Quarterly
Mercury	0.0016	0.002	mg/l	Quarterly	Quarterly
Nickel	0.08	0.1	mg/l	Quarterly	Quarterly
Selenium	0.04	0.05	mg/l	Quarterly	Quarterly
Thallium	0.0016	0.002	mg/l	Quarterly	Quarterly

⁴⁷ AL = Alert Level

⁴⁸ AQL = Aquifer Quality Limit

⁴⁹ To be determined based upon the completion of compliance Item No. 3.5.

⁵⁰ NE = Not Established. Monitoring is required, but no limits are specified.

⁵¹ Total Nitrogen is equal to nitrate as N plus nitrite as N plus TKN.

⁵² P/A = Presence or absence of total coliform in a 100-milliliter sample.

4.2 COMPLIANCE (or OPERATIONAL) MONITORING

**TABLE IIB
ROUTINE GROUNDWATER MONITORING (continued)**

Parameter	AL	AQ	Units	Sampling Frequency	Reporting Frequency
Volatile Organic Compounds (VOCs):					
Benzene	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
Carbon tetrachloride	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
o-Dichlorobenzene	0.48	0.6	mg/l	Semi-Annually	Semi-Annually
para-Dichlorobenzene	0.06	0.075	mg/l	Semi-Annually	Semi-Annually
1,2-Dichloroethane	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
1,1-Dichloroethylene	0.0056	0.007	mg/l	Semi-Annually	Semi-Annually
cis-1,2-Dichloroethylene	0.056	0.07	mg/l	Semi-Annually	Semi-Annually
trans-1,2-Dichloroethylene	0.08	0.1	mg/l	Semi-Annually	Semi-Annually
Dichloromethane	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
1,2-Dichloropropane	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
Ethylbenzene	0.56	0.7	mg/l	Semi-Annually	Semi-Annually
Hexachlorobenzene	0.0008	0.001	mg/l	Semi-Annually	Semi-Annually
Hexachlorocyclopentadiene	0.04	0.05	mg/l	Semi-Annually	Semi-Annually
Monochlorobenzene	0.08	0.1	mg/l	Semi-Annually	Semi-Annually
Styrene	0.08	0.1	mg/l	Semi-Annually	Semi-Annually
Tetrachloroethylene	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
Toluene	0.8	1.0	mg/l	Semi-Annually	Semi-Annually
Trihalomethanes (total) ⁵³	0.08	0.1	mg/l	Semi-Annually	Semi-Annually
1,1,1-Trichloroethane	0.16	0.2	mg/l	Semi-Annually	Semi-Annually
1,2,4 - Trichlorobenzene	0.056	0.07	mg/l	Semi-Annually	Semi-Annually
1,1,2 - Trichloroethane	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
Trichloroethylene	0.004	0.005	mg/l	Semi-Annually	Semi-Annually
Vinyl Chloride	0.0016	0.002	mg/l	Semi-Annually	Semi-Annually
Xylenes (Total)	8.0	10.0	mg/l	Semi-Annually	Semi-Annually

⁵³Total Trihalomethanes are comprised of Bromoform, Bromodichloromethane, Chloroform, and Dibromochloromethane.

4.2 COMPLIANCE (or OPERATIONAL) MONITORING

**TABLE IIB
ROUTINE GROUNDWATER MONITORING (continued)**

Parameter	AL	AQL	Units	Sampling Frequency	Reporting Frequency
Indicator Parameters / Major Cations and Anions:					
pH (field)	Monitor ⁵⁴	Monitor	S.U.	Quarterly	Quarterly
Iron	Monitor	Monitor	mg/l	Quarterly	Quarterly
Manganese	Monitor	Monitor	mg/l	Quarterly	Quarterly
Total Organic Carbon	Monitor	Monitor	mg/l	Quarterly	Quarterly
Total Dissolved Solids	Monitor	Monitor	mg/l	Quarterly	Quarterly
Sodium	Monitor	Monitor	mg/l	Quarterly	Quarterly
Potassium	Monitor	Monitor	mg/l	Quarterly	Quarterly
Calcium	Monitor	Monitor	mg/l	Quarterly	Quarterly
Magnesium	Monitor	Monitor	mg/l	Quarterly	Quarterly
Chloride	Monitor	Monitor	mg/l	Quarterly	Quarterly
Sulfate	Monitor	Monitor	mg/l	Quarterly	Quarterly
Alkalinity	Monitor	Monitor	mg/l	Quarterly	Quarterly
Specific Conductivity (field)	Monitor	Monitor	µmhos/cm	Quarterly	Quarterly

⁵⁴ Monitoring is required, but no limits have been established.

4.2 COMPLIANCE (or OPERATIONAL) MONITORING

TABLE III
FACILITY INSPECTION (Operational Monitoring)

Pollution Control Structures/Parameter	Performance Levels	Inspection Frequency	Reporting Frequency
Pump Integrity	Good working condition	Weekly	Quarterly
Treatment Plant Components	Good working condition	Weekly	Quarterly
Holding Pond Berm Integrity	No visible structural damage, breach, or erosion of embankments	Weekly	Quarterly
Liner Integrity of Effluent Holding Ponds	No cracks or leaks that would exceed a leakage rate of 550 gpd/acre	Weekly	Quarterly

5.0 REFERENCES AND PERTINENT INFORMATION

The terms and conditions set forth in this permit have been developed based upon the information contained in the following, which are on file with the Department:

1. APP Application, dated: April 3, 1998 (original APP, signed on 03/02/99)
June 3, 2003 (Other Amend, signed 11/25/03)
December 16, 2004 (Signif. Amend., signed 11/18/05)
March 13, 2007 (Significant Amendment)
2. Contingency Plan, dated: December 5, 2003
3. Final Hydrologist Report, dated: December 22, 2003
June 4, 2009 (Signif. Amend.)
4. Final Engineering Report, dated: February 2, 2004
May 27, 2008 (Signif. Amend)
5. Public Notice, dated: February 26, 2004 (APP)
[REDACTED] (Signif. Amend.)
6. Public Hearing, dated: Not applicable.
7. Responsiveness Summary, dated: Not applicable.

6.0 NOTIFICATION PROVISIONS

6.1 Annual Registration Fees

The permittee is notified of the obligation to pay an Annual Registration Fee to ADEQ. The Annual Registration Fee is based upon the amount of daily influent or discharge of pollutants in gpd as established by A.R.S. § 49-242(D).

6.2 Duty to Comply [A.R.S. §§ 49-221 through 263]

The permittee is notified of the obligation to comply with all conditions of this permit and all applicable provisions of Title 49, Chapter 2, Articles 1, 2 and 3 of the Arizona Revised Statutes, Title 18, Chapter 9, Articles 1 through 4, and Title 18, Chapter 11, Article 4 of the Arizona Administrative Code. Any permit non-compliance constitutes a violation and is grounds for an enforcement action pursuant to Title 49, Chapter 2, Article 4 or permit amendment, suspension, or revocation.

6.3 Duty to Provide Information [A.R.S. §§ 49-243(K)(2) and 49-243(K)(8)]

The permittee shall furnish to the Director, or an authorized representative, within a time specified, any information which the Director may request to determine whether cause exists for amending or terminating this permit, or to determine compliance with this permit. The permittee shall also furnish to the Director, upon request, copies of records required to be kept by this permit.

6.4 Compliance with Aquifer Water Quality Standards [A.R.S. §§ 49-243(B)(2) and 49-243(B)(3)]

The permittee shall not cause or contribute to a violation of an AWQS at the applicable POC for the facility. Where, at the time of issuance of the permit, an aquifer already exceeds an AWQS for a pollutant, the permittee shall not discharge that pollutant so as to further degrade, at the applicable point of compliance for the facility, the water quality of any aquifer for that pollutant.

6.5 Technical and Financial Capability

[A.R.S. §§ 49-243(K)(8) and 49-243(N) and A.A.C. R18-9-A202(B) and R18-9-A203(E) and (F)]

The permittee shall have and maintain the technical and financial capability necessary to fully carry out the terms and conditions of this permit. Any bond, insurance policy, trust fund, or other financial assurance mechanism provided as a demonstration of financial capability in the permit application, pursuant to A.A.C. R18-9-A203(D), shall be in effect prior to any discharge authorized by this permit and shall remain in effect for the duration of the permit.

6.6 Reporting of Bankruptcy or Environmental Enforcement [A.A.C. R18-9-A207(C)]

The permittee shall notify the Director within five days after the occurrence of any one of the following:

1. the filing of bankruptcy by the permittee; or
2. the entry of any order or judgment not issued by the Director against the permittee for the enforcement of any environmental protection statute or rule.

6.7 Monitoring and Records [A.R.S. § 49-243(K)(8) and A.A.C. R18-9-A206]

The permittee shall conduct any monitoring activity necessary to assure compliance with this permit, with the applicable water quality standards established pursuant to A.R.S. §§ 49-221 and 49-223 and §§ 49-241 through 49-252.

6.8 Inspection and Entry [A.R.S. §§ 41-1009, 49-203(B), and 49-243(K)(8)]

In accordance with A.R.S. §§ 41-1009 and 49-203(B), the permittee shall allow the Director, or an authorized representative, upon the presentation of credentials and other documents as may be required by law, to enter and inspect the facility as reasonably necessary to ensure compliance with Title 49, Chapter 2, Article 3 of the Arizona Revised Statutes, and Title 18, Chapter 9, Articles 1 through 4 of the Arizona Administrative Code and the terms and conditions of this permit.

6.9 Duty to Modify [A.R.S. § 49-243(K)(8) and A.A.C. R18-9-A211]

The permittee shall apply for and receive a written amendment before deviating from any of the designs or operational practices authorized by this permit.

**6.10 Permit Action: Amendment, Transfer, Suspension, and Revocation
[A.R.S. §§ 49-201, 49-241 through 251, A.A.C. R18-9-A211, R18-9-A212 and R18-9-A213]**

This permit may be amended, transferred, suspended, or revoked for cause, under the rules of the Department. The permittee shall notify the Groundwater Section in writing within 15 days after any change in the owner or operator of the facility. The notification shall state the permit number, the name of the facility, the date of property transfer, and the name, address, and phone number where the new owner or operator can be reached. The operator shall advise the new owner or operators of the terms of this permit and the need for permit transfer in accordance with the rules.

7.0 ADDITIONAL PERMIT CONDITIONS

7.1 Other Information [A.R.S. § 49-243(K)(8)]

Where the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Director, the permittee shall promptly submit the correct facts or information.

7.2 Severability [A.R.S. §§ 49-201, 49-241 through 251, A.A.C. R18-9-A211, R18-9-A212 and R18-9-A213]

The provisions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby. The filing of a request by the permittee for a permit action does not stay or suspend the effectiveness of any existing permit condition.

7.3 Permit Transfer

This permit may not be transferred to any other person except after notice to and approval of the transfer by the Department. No transfer shall be approved until the applicant complies with all transfer requirements as specified in A.A.C. R18-9-A212(B) and (C).