

INSTRUCTIONS

Please fill out and submit this Application for Approval to Construct Drinking Water Facilities (ATC) to obtain authorization to construct a public drinking water system in accordance with Arizona Administrative Code (A.A.C.) R18-5-505.

GENERAL APPLICATION PROCESS

1. Submit this ATC and appropriate supplemental information and forms, which are identified in this form. Please refer for Form 222 (<http://www.azdeq.gov/environ/water/permits/download/222.pdf>) for guidance on what should be submitted with this application and the number of copies. Please see the document entitled Application Submittal Locations (<http://www.azdeq.gov/environ/water/permits/download/appsub.pdf>) to determine where to submit your application (County, City, or ADEQ Regional Office).
2. The following is a tabulation of fees for drinking water systems:

Fee Category (R18-14-202)	Fee ^{a, b}
Approval to Construct for a Public Water Distribution System:	
o 150 or fewer service connections	\$900
o 151 to 300 service connections	\$1,400
o 301 to 450 service connections	\$1,900
o 451 to 600 service connections	\$2,400
o 601 to 750 service connections	\$2,900
o Each additional 150 service connections	Add \$500
Water Treatment Plants and Blending Plans (including new source approval if applicable):	
o < 0.1 Million gallons per day (MGD)	\$1,500
o ≥ 0.1 MGD and < 1.0 MGD	\$2,000
o ≥ 1.0 MGD and < 5.0 MGD	\$3,000
o ≥ 5.0 MGD	\$5,000
Well (including new source approval if applicable), each	\$1,250
Storage Tank, each	\$800
Booster Pump, each	\$800
Main Line Extension (for minor water line extensions only)	\$250
Chlorinators/Disinfection Devices, each	\$250
Extension of Time to Construct ^c	50% of the application fee, not to exceed \$500
Priority Review Fee ^d	Double the Standard Fee

Notes:

- a. Fees are calculated on a per-unit basis: i.e., a separate fee is assessed for each separate storage tank, booster pump, disinfection device or well.
 - b. Fees for each application type are cumulative; an applicant must pay the total of all pertinent fees.
 - c. Extensions of time to construct are issued pursuant to A.A.C. R18-5-505(E): the Section states that an Approval to Construct becomes void if construction is not commenced within a specific time period, unless the Department grants an extension of time.
 - d. Priority Review projects require Department authorization prior to filing.
3. Satisfy any deficiency requests arising from the Department’s pre-construction review of the submitted information.
 4. Receive an “Approval to Construct (ATC)” from the Department authorizing construction of the water distribution system.
 5. Begin construction of the water system within one year of the signed approval to construct and complete construction within three years from signed Approval to Construct (ATC).



ENGINEERING REVIEW SECTION
APPLICATION FOR APPROVAL TO CONSTRUCT
DRINKING WATER FACILITIES
 ADEQ/WQD-114DW

LICENSING TIME FRAMES

Licensing Time Frames are specified by Arizona Department of Environmental Quality in AAC R18-1-525, which limits the number of business days ADEQ can review your project without a penalty. They are:

License Type	Administrative Review	Substantive Review	Overall Time Frame
Approval to Construct drinking water treatment facility, project or well.			
Standard	16	37	53
Complex	16	67	83
Drinking Water New Source Approval			
Standard	16	37	53
Complex	16	67	83
Time Extension Approval			
Standard	16	16	32

HOW TO NAME YOUR PROJECT

Name the project according to one of the following guidelines:

1. If a distribution system serves a specific subdivision, assign the same name "XXX Subdivision."
2. If a distribution system serves a specific facility, assign that name "XXX RV Park" or "...XXX Campground" or "...XXX Shopping Center."
3. If a water main that does not directly service any residences or other facilities but which will enable facilities and their water mains further upstream to connect to a water line extension: "XXX 'Water Line Extension."



ENGINEERING REVIEW SECTION
APPLICATION FOR APPROVAL TO CONSTRUCT
DRINKING WATER FACILITIES
 ADEQ/WQD-114DW

GENERAL INFORMATION

1 Project Information Standard review Priority review Time extension (renewal)

Project Name: _____
 Project Description: _____

This project is funded by the American Recovery and Reinvestment Act of 2009

2 Applicant (Owner or Developer)

Name: _____ Phone: _____
 Title: _____ Firm Name: _____
 Mailing Address: _____
 City: _____ State: _____ Zip: _____
 E-mail Address: _____

3 Applicant's Agent, if any (Engineer or Consultant)

Name: _____ Phone: _____
 Arizona BTR Registration Number: _____ Fax: _____
 Title: _____ Firm Name: _____
 Mailing Address: _____
 City: _____ State: _____ Zip: _____
 E-mail Address: _____

4 Site Information

County: _____ Nearest City: _____
 Township: _____ Range: _____ Section: _____, Quarter Section: _____ NE SE SW NW
 Latitude: _____ ° _____ ' _____ " N Longitude: _____ ° _____ ' _____ " W

5 Existing Environmental Permits (Check One)

List any other federal or state environmental permits issued for or needed by the facility, including any related Approvals to Construct (ATCs) or Approvals of Construction (AOCs) that may have previously been authorized and are related to this application (attach additional pages or copies if necessary)

DEPARTMENT USE ONLY		DATE STAMP
File Number		
Fee Paid for this Project		
Check Total		
Date Compliance Status Request Sent		



ENGINEERING REVIEW SECTION
APPLICATION FOR APPROVAL TO CONSTRUCT
DRINKING WATER FACILITIES
 ADEQ/WQD-114DW

Water Treatment Plant Information **Surface Water** **Well Water**

A) Please select the capacity of the treatment plant:

- < 0.1 Million gallons per day (MGD)
- 0.1 to <1.0 MGD
- 1.0 to <5.0 MGD
- ≥ 5.0 MGD

B) Indicate the inorganic/organic contaminant(s) for treatment.

Contaminant	Lab Result (ppb)	Technology Used to Treat (Filtration, RO, Absorptive Media, Ion Exchange, etc)	Predicted Final Treatment Value (ppb)

Blending Plan Information

A) Please select the capacity of the blending plan:

- < 0.1 MGD
- 0.1 to <1.0 MGD
- 1.0 to <5.0 MGD
- ≥ 5.0 MGD

Well Approval Information

- New Source Approval.
 1. I have attached a copy of the ADWR Notice of Intent to Drill Well (NOI)
 2. ADWR Well # 55-_____
 3. Water test results submitted, or Water test results will be submitted with the AOC application
 4. Capacity Development Application has been submitted
- Existing Well.
 1. Change of Status Form Included (if Applicable)
 2. ADWR Well # 55-_____

Storage Tank Information

A) Please indicate the following information for the storage tanks associated with this project:

Tank Number	Tank Capacity (gallons)	Material of Construction	Liner Material or Corrosion Protection

Booster Pump Information

A) Please include the details for each booster pump:

Pump Number	Pump Rated Capacity	Horsepower	Manufacturer	Model #

Chlorinator and/or Disinfection System Information

- Gas Tablet

ATC Time Frame Extension Information

Original ADEQ File # _____

Priority Review Fee Information

- The fees included are double the standard fees for all items for review

11 Construction Quality Drawings (Check Box if Complete)

- a. The engineering plans must be final plans. Plans marked preliminary, not for construction or similar languages will not be reviewed.
- b. Specifications are included in the construction drawings and/or are a separate attachment;
- c. The profiles of all waterlines 10" and greater must be shown on engineering plans.
- d. The plans must include thrust block details, pipe bedding details, blow-off valves (as caps will not be accepted) and air release vales (ARV) are required at all high points.
- e. Backflow in accordance with R-18-4-115

I have provided all the information listed in a. though d. above.

12 Water Distribution System Design Flows (Check Box if Complete)

I have attached documentation of design and fire flows for significant components of the drinking water distribution system and the basis for calculating the design flows.

13 Design Report (Check Box if Complete)

I have included design documents, including plans, specifications, drawings, reports, and calculations that are signed, dated, and sealed by an Arizona-registered professional engineer. The designer shall use good engineering judgment following engineering standards of practice, and rely on appropriate engineering methods, calculations, and guidance. A design report will describe the proposed construction and basis of design, provide design data and other pertinent information that defines the work to be done, and establishes the adequacy of the design to meet the system demand. A design report provides information such as water pressure of existing waterline, minimum water pressure during fire flow, water capacity required to fulfill overall water needs, etc.

