

ADEQ Inventory No. 100574
LTF No. 63925

Permit No. AZ0025313
Place ID No. 971

AUTHORIZATION TO DISCHARGE UNDER THE ARIZONA POLLUTANT DISCHARGE ELIMINATION SYSTEM

In compliance with the provisions of Arizona Revised Statutes (A.R.S.) Title 49, Chapter 2, Article 3.1; the Federal Water Pollution Control Act, (33 USC §1251 et. seq., as amended), and Arizona Administrative Code (A.A.C.) Title 18, Chapter 9, Articles 9 and 10, and amendments thereto,

City of Buckeye
Central Buckeye Wastewater Treatment Plant
423 Arizona Eastern Avenue
Buckeye, Arizona 85326

is authorized to discharge treated domestic wastewater from the wastewater treatment plant located at 915 S. 7th Street, Buckeye, Arizona serving the City of Buckeye in Maricopa County, Arizona to the Buckeye Canal, tributary to the Arlington Canal, and Roosevelt Canal, in the Middle Gila River Basin at:

Outfall No.	Latitude	Longitude	Legal
002 – Lateral of Buckeye Canal	33° 21' 32" N	112° 34' 55" W	Township 1 S, Range 3 W, Section 8
003 – Roosevelt Canal	33° 25' 26.751" N	112° 31' 4.795" W	Township 1 N, Range 3 W, Section 13
004 – Buckeye Canal	33° 23' 23" N	112° 31' 18" W	Township 1 N, Range 3 W, Section 35

in accordance with effluent limitations, monitoring requirements and other conditions set forth herein, and in the attached "Standard AZPDES Permit Conditions."

Annual Registration Fee [A.R.S. 49-255.01 and A.A.C. R18-14-104]

The annual registration fee for this permit is payable to ADEQ each year. The permitted flow for fee calculation is 4,500,000 gallons per day (gpd). If the facility is not yet constructed or is incapable of discharge at this time, the permittee may be eligible for reduced fees under rule. Send all correspondence requesting reduced fees to the Water Quality Division of ADEQ. Please reference the permit number, LTF number and why reduced fees are requested under rule.

This permit became effective on March 27, 2015.

The permit modification date shall become effective on _____, 2016.

This permit and the authorization to discharge shall expire at midnight March 26, 2020.

Signed this _____ day of _____, 2016.

Trevor Baggio, Director
Water Quality Division
Arizona Department of Environmental Quality

TABLE OF CONTENTS

EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS	4
Effluent Limitations and Monitoring Requirements.....	4
Trace Substance Monitoring Requirements.....	5
Effluent Characterization Testing - General Chemistry and Microbiology.....	5
Effluent Characterization Testing - Selected Metals & Trace Substances	6
Effluent Characterization Testing - Selected Volatile Organic Compounds.....	6
Effluent Characterization Testing - Selected Acid-extractable Compounds	7
Effluent Characterization Testing - Selected Base Neutral Compounds	8
Effluent Characteristic Testing Based on Designated Uses	10
Narrative Standards	10
Sampling Location(s)	11
MONITORING AND REPORTING	11
Sample Collection and Analysis	11
QA Manual	11
Use of Approved Methods	12
LOQs.....	13
Reporting of Monitoring Results	13
Twenty-four Hour Reporting of Noncompliance	15
Monitoring Records.....	16
BIOSOLIDS /SEWAGE SLUDGE REQUIREMENTS	16
Use or Disposal Requirements.....	16
Biosolids Preparer's Responsibility.....	17
Duty to Mitigate	17
General Requirements.....	17
Biosolids Storage	17
Surface Water Protection.....	18
Facilities with Pretreatment Programs	18
Inspection and Entry	19
General Biosolids Monitoring Requirements	19
Biosolids Self-monitoring Frequency.....	19
Sampling and Analyses Methods.....	19
Representative Sampling.....	20
Testing Stockpiled Biosolids Prior to Distribution or Use.....	20
Testing for Hazardous Waste Determination.....	20
Biosolids Limitations and Monitoring	22
Metals Concentrations for Land Application	22
Pathogen Reduction Requirements for Land Application.....	23

Vector Reduction Records	25
Nitrogen Testing	25
Management Practices for Land Application	25
Biosolids/Sewage Sludge Limitations and Monitoring Requirements for Surface Disposal	26
Biosolids Monitoring Requirements for Disposal in a Municipal Landfill	26
On-site Management Plan	26
Record Keeping	26
Notification Requirements	26
Notification of Noncompliance	27
Notification of Shipment to Another State	27
Notification of Changes in Land Application Sites, or Disposal Methods	27
Notification for Land Application of Biosolids with High Metals	28
Notification to Subsequent Land Applicators	28
Notice of Surface Disposal	28
Annual Report for All Permittees	28
Reporting Locations	29
SPECIAL CONDITIONS	30
Operation	30
Reopener	30
APPENDIX A	31
PART A: ACRONYMS	31
PART B: DEFINITIONS	31
APPENDIX B	34
Ammonia Data Log	36
Ammonia Standard Tables	35
APPENDIX C	ATTACHED
STANDARD CONDITIONS	

PART I. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

A. Effluent Limitations and Monitoring Requirements

The permittee shall limit and monitor discharges from Outfall 002, Outfall 003 and Outfall 004 as specified in Table 1 which follows. These requirements are based on a design capacity of 17,033 m³/day (4.5 MGD).

TABLE 1: Effluent Limitations and Monitoring Requirements

Parameter	Maximum Allowable Discharge Limitations						Monitoring Requirement (2)	
	Mass Limits (1)			Concentration Limits				
	Monthly Average	Weekly Average	Daily Maximum	Monthly Average	Weekly Average	Daily Maximum	Monitoring Frequency	Sample Type
Discharge Flow (MGD)	REPORT (3)	---	REPORT	---	---	---	Continuous	Metered
Biochemical Oxygen Demand (BOD) (5-day)	510 kg/day	770 kg/day	---	30 mg/L	45 mg/L	---	1x/2 weeks	24-hour Composite (4)
BOD (5)	---	---	---	85% REMOVAL MINIMUM	---	---	1x/2 weeks	24-hour Composite
Total Suspended Solids (TSS)	510 kg/day	770 kg/day	---	30 mg/L	45 mg/L	---	1x/2 weeks	24-hour Composite
TSS (5)	---	---	---	85% REMOVAL MINIMUM	---	---	1x/2 weeks	24-hour Composite
<i>E. coli</i>	---	---	---	126 cfu/100 mL (6)	---	575 cfu/100 mL (6)	4x/month	Discrete
Oil & Grease	170 kg/day	---	260 kg/day	10 mg/L	---	15 mg/L	1x/quarter	Discrete
Chlorine, Total Residual (TRC) (7) (8)	150 g/day	---	310 g/day	9.0 µg/L	---	18 µg/L	1x/week	Discrete
Boron	20970 g/day	---	28659 g/day	1231 µg/L	---	1682 µg/L	1x/quarter	24-hour Composite
Selenium	30 g/day	---	70 g/day	2 µg/L	---	4 µg/L	1x/quarter	24-hour Composite
pH (7)	Not less than 6.5 standard units (S.U.) nor greater than 9.0 S.U.						1x/week	Discrete

Footnotes:

- (1) Mass values are to be calculated and reported using the following formulas: 1) Mass in kilograms per day = 3.785 x flow in MGD x concentration in mg/L, and 2) mass in grams per day = 3.785 x flow in MGD x concentration in µg/L.
- (2) If discharge is infrequent, see Part I.C for minimum effluent characterization monitoring requirements.
- (3) Monitoring and reporting required. No limit set at this time. The average and maximum flows shall be reported on the Discharge Monitoring Report (DMR) forms. See Part II.B for reporting requirements.
- (4) For the purposes of this permit, a "24-hour composite" sample has been defined as a flow-proportioned mixture of not less than three discrete samples (aliquots) obtained at equal time intervals during a 24-hour period. The volume of each aliquot shall be directly proportional to the discharge flow rate at the time of sampling.
- (5) Both the influent and the effluent shall be monitored.

- (6) cfu = colony forming units; "most probable number" (mpn) is considered equivalent for reporting purposes. The monthly average for *E. coli* is calculated as a geometric mean. A minimum of 4 samples are required in order to report a geometric mean. See the definition for "Monthly or Weekly Average Concentration Limit" in Appendix A.
- (7) pH and TRC must be measured at the time of sampling and do not require use of a certified laboratory. Measurements must be obtained in accordance with the applicable method and must meet all method quality assurance / quality control requirements to be considered valid data.
- (8) Sample when chlorine or bromine compounds are used for disinfection. See Part II.A.5 for specific monitoring requirements for chlorine.

B. Effluent Characterization Testing

The permittee shall monitor to characterize the facility's effluent for the parameters listed in Tables 2.a - c, whether discharging or not. When the facility discharges, monitoring is to be conducted at the frequency indicated in Tables 1 and 2. No limits or ALs are established, but the LOQ must be low enough to allow comparison of the results to the applicable surface water quality standards (SWQS). If a LOQ below the SWQS cannot be achieved, then the permittee shall use the method expected to achieve the lowest LOQ, as defined in Appendix A of this permit. Samples are to be representative of any seasonal variation in the discharge:

TABLE 2.a: Effluent Characterization Testing – General Chemistry and Microbiology

Parameter	Reporting Units	Monitoring Requirements	
		Monitoring Frequency (1)	Sample Type
Ammonia (as N) (5)	mg/L	1x/quarter	Discrete
Biochemical Oxygen Demand (BOD-5)	mg/L	1x/quarter	24-hour Composite
Chlorine, Total Residual (TRC) (2) (4)	µg/L	1x/quarter	Discrete
Dissolved Oxygen (2)	mg/L	1x/quarter	Discrete
<i>E. coli</i>	cfu/100 mL (3)	1x/quarter	Discrete
Nitrogen, Total Kjeldahl (TKN)	mg/L	1x/quarter	24-hour Composite
Oil and Grease	mg/L	1x/quarter	Discrete
pH (2) (5)	S.U.	1x/quarter	Discrete
Phosphorus	mg/L	1x/quarter	24-hour Composite
Temperature (2) (5)	°Celsius	1x/quarter	Discrete
Total Dissolved Solids (TDS)	mg/L	1x/quarter	24-hour Composite
Total Suspended Solids (TSS)	mg/L	1x/quarter	24-hour Composite

Footnotes:

- (1) If more frequent monitoring of any of these parameters is required by another part of this permit, those sampling results may be used to satisfy Table 2.a requirements.
- (2) Temperature, pH, TRC and dissolved oxygen must be measured at the time of sampling and do not require use of a certified laboratory. See Part II.A.5 for methods of analyses for chlorine. Measurements must be obtained in accordance with the applicable method and must meet all method quality assurance / quality control requirements to be considered valid data.
- (3) cfu = colony forming units; "most probable number" (mpn) is considered equivalent for reporting purposes.
- (4) Sample when chlorine or bromine compounds are used for disinfection. See Part II.A.5 for specific monitoring requirements for chlorine.
- (5) When sampling for ammonia, temperature and pH must be determined concurrently and the results recorded on the **Ammonia Data Log** provided in Appendix B. See Part II.B for reporting requirements.

TABLE 2.b: Effluent Characterization Testing - Selected Metals and Trace Substances

Parameter (1)	Reporting Units	Monitoring Requirements	
		Monitoring Frequency (2)	Sample Type
Antimony	µg/L	1x/6 months	24-hour Composite
Arsenic	µg/L	1x/6 months	24-hour Composite
Beryllium	µg/L	1x/6 months	24-hour Composite
Boron	µg/L	1x/6 months	24-hour Composite
Cadmium	µg/L	1x/6 months	24-hour Composite
Chromium	µg/L	1x/6 months	24-hour Composite
Chromium VI	µg/L	1x/6 months	Discrete
Copper	µg/L	1x/6 months	24-hour Composite
Iron	µg/L	1x/6 months	24-hour Composite
Lead	µg/L	1x/6 months	24-hour Composite
Mercury	µg/L	1x/6 months	Discrete
Nickel	µg/L	1x/6 months	24-hour Composite
Selenium	µg/L	1x/6 months	24-hour Composite
Silver	µg/L	1x/6 months	24-hour Composite
Thallium	µg/L	1x/6 months	24-hour Composite
Zinc	µg/L	1x/6 months	24-hour Composite
Cyanide	µg/L	1x/6 months	Discrete

Footnotes:

- (1) All metals analyses shall be for total recoverable metals, except chromium VI, which is dissolved.
- (2) If more frequent monitoring of any of these parameters is required by another part of this permit, those sampling results may be used to satisfy Table 2.b. requirements.

TABLE 2.c: Effluent Characterization Testing - Selected Volatile Organic Compounds

Parameter	Reporting Units	Monitoring Requirements	
		Monitoring Frequency	Sample Type
Acrolein	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	Discrete
Acrylonitrile	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	Discrete
Benzene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	Discrete
Bromoform	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	Discrete
Carbon tetrachloride	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	Discrete
Chlorobenzene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	Discrete
Chlorodibromomethane	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	Discrete

Chloroethane	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	Discrete
2-chloroethylvinyl ether	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	Discrete
Chloroform	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	Discrete
Dichlorobromomethane	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	Discrete
1,1-dichloroethane	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	Discrete
1,2-dichloroethane	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	Discrete
Trans-1,2-dichloroethylene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	Discrete
1,1-dichloroethylene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	Discrete
1,2-dichloropropane	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	Discrete
1,3-dichloropropylene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	Discrete
Ethylbenzene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	Discrete
Methyl bromide	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	Discrete
Methyl chloride	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	Discrete
Methylene chloride	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	Discrete
1,1,2,2-tetrachloroethane	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	Discrete
Tetrachloroethylene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	Discrete
Toluene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	Discrete
1,1,1-trichloroethane	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	Discrete
1,1,2-trichloroethane	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	Discrete
Trichloroethylene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	Discrete
Vinyl chloride	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	Discrete

TABLE 2.d: Effluent Characterization Testing - Selected Acid-extractable Compounds

Parameter	Reporting Units	Monitoring Requirements	
		Monitoring Frequency	Sample Type
P-chloro-m-cresol	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
2-chlorophenol	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite

TABLE 2.d: Effluent Characterization Testing - Selected Acid-extractable Compounds

2,4-dichlorophenol	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
2,4-dimethylphenol	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
4,6-dinitro-o-cresol	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
2,4-dinitrophenol	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
2-nitrophenol	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
4-nitrophenol	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Pentachlorophenol	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Phenol	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
2,4,6- trichlorophenol	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite

TABLE 2.e: Effluent Characterization Testing - Selected Base-neutral Compounds

Parameter	Reporting Units	Monitoring Requirements	
		Monitoring Frequency	Sample Type
Acenaphthene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Acenaphthylene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Anthracene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Benzidine	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Benzo(a)anthracene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Benzo(a)pyrene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
3,4 benzofluoranthene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Benzo(ghi)perylene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Benzo(k)fluoranthene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Bis (2-chloroethoxy) methane	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Bis (2-chloroethyl) ether	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Bis(2-chloroisopropyl) ether	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Bis (2-ethylhexyl) phthalate	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
4-bromophenyl phenyl ether	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Butyl benzyl phthalate	µg/L	1x /year in years 2016, 2017, and 2018	24-hour Composite

		of permit term	
2-chloronaphthalene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
4-chlorophenyl phenyl ether	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Chrysene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Di-n-butyl phthalate	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Di-n-octyl phthalate	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Dibenzo(a,h)anthracene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
1,2-dichlorobenzene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
1,3-dichlorobenzene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
1,4-dichlorobenzene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
3,3-dichlorobenzidine	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Diethyl phthalate	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Dimethyl phthalate	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
2,4-dinitrotoluene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
2,6-dinitrotoluene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
1,2-diphenylhydrazine	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Fluoranthene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Fluorene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Hexachlorobenzene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Hexachlorobutadiene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Hexachlorocyclopentadiene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Hexachloroethane	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Indeno(1,2,3-cd)pyrene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Isophorone	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Naphthalene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Nitrobenzene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
N-nitrosodi-n-propylamine	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite

N-nitrosodimethylamine	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
N-nitrosodiphenylamine	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Phenanthrene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Pyrene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
1,2,4-trichlorobenzene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite

TABLE 2.f: Effluent Characteristic Testing Based on Designated Uses

Additional Parameters from the Arizona Surface Water Quality Standards, Appendix A: Table 1

Parameter	Reporting Units	Monitoring Requirements	
		Monitoring Frequency	Sample Type
Aldrin	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Benzidine	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
4,4-DDD (p,p,- Dichlorodiphenyldichloroethane)	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
4,4-DDE (p,p- Dichlorodiphenyldichloroethylene)	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
4,4-DDT (p,p- Dichlorodiphenyltrichloroethane)	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Dieldrin	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Endrin	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Polychlorinated biphenyls (PCBs)	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite
Toxaphene	µg/L	1x /year in years 2016, 2017, and 2018 of permit term	24-hour Composite

D. The discharge shall be free from pollutants in amounts or combinations that:

1. Settle to form bottom deposits that inhibit or prohibit the habitation, growth or propagation of aquatic life;
2. Cause objectionable odor in the area in which the surface water is located;
3. Cause off-flavor in aquatic organisms;
4. Are toxic to humans, animals, plants or other organisms;
5. Cause the growth of algae or aquatic plants that inhibit or prohibit the habitation, growth or propagation of other aquatic life or that impair recreational uses.

- E.** The discharge shall be free from oil, grease and other pollutants that float as debris, foam, or scum; or that cause a film or iridescent appearance on the surface of the water; or that cause a deposit on a shoreline, bank or aquatic vegetation.
- F.** Samples taken for the monitoring requirements specified in Part I shall be collected at the following locations:
1. Influent samples shall be taken after the last addition to the collection system and prior to the first treatment process.
 2. Effluent samples shall be taken downstream from the last treatment process and prior to mixing with the receiving waters.

PART II. MONITORING AND REPORTING

A. Sample Collection and Analysis

1. The permittee is responsible for the quality and accuracy of all data required under this permit.
2. Quality Assurance (QA) Manual

The permittee shall keep a QA Manual on site that describes the sample collection and analyses processes. If the permittee collects samples or conducts sample analyses in house, the permittee shall develop a QA Manual that addresses these activities. If a third party collects and/or analyzes samples on behalf of the permittee, the permittee shall obtain a copy of the applicable QA procedures. The QA Manual shall be available for review by ADEQ upon request. The QA Manual shall be updated as necessary to reflect current conditions, and shall describe the following:

- a. Project Management, including:
 - Purpose of sample collection and sample frequency;
 - When and where samples will be collected;
 - How samples will be collected;
 - Who will collect samples and their qualifications;
 - Laboratory(s) that will perform analyses;
 - Any field tests to be conducted (detail methods and specify equipment, including a description of any needed calibrations); and
 - Pollutants or analytes being measured and for each, the permit-specific limits, Assessment Levels, or thresholds, (e.g. the associated detection limits needed.)
- b. Sample collection procedures, including:
 - Equipment to be used;
 - Type and number of samples to be collected including QA/QC samples (i.e., background samples, duplicates, and equipment or field blanks);

- Types, sizes, and number of sample bottles needed;
 - Preservatives and holding times for the samples (see methods under 40 CFR 136 or 9 A.A.C. 14, Article 6 or any condition within this permit that specifies a particular test method); and
 - Chain of custody procedures.
- c. Specify approved analytical method(s) to be used and include:
- Limits of Detection (LOD) and Limits of Quantitation (LOQs);
 - Required quality control (QC) results to be reported (e.g., matrix spike recoveries, duplicate relative percent differences, blank contamination, laboratory control sample recoveries, surrogate spike recoveries, etc.) and acceptance criteria; and
 - Corrective actions to be taken by the permittee or the laboratory as a result of problems identified during QC checks.
- d. How the permittee will perform data review; complete DMRs and records used to report results to ADEQ; resolve data quality issues; and identify limitations on the use of the data.
3. Sample collection, preservation and handling shall be performed as described in 40 CFR 136 including the referenced Edition of *Standard Methods for the Examination of Water and Wastewater*, or by procedures referenced in A.R.S Title 9, Chapter 14 of the Arizona Department of Health Services (ADHS) Laboratory Licensure rules. The permittee shall outline the proper procedures in the QA Manual, and samples taken for this permit must conform to these procedures whether collection and handling is performed directly by the permittee or contracted to a third-party.
4. Analytical requirements
- a. The permittee shall use a laboratory licensed by the ADHS Office of Laboratory Licensure and Certification that has demonstrated proficiency within the last 12 months under R9-14-609, for each parameter to be sampled under this permit. However, this requirement does not apply to parameters which require analysis at the time of sample collection as long as the testing methods used are approved by ADHS and ADEQ. (These parameters may include flow, dissolved oxygen, pH, temperature, and total residual chlorine.)
- b. The permittee must utilize analytical methods specified in this permit. If no test procedure is specified, the permittee shall analyze the pollutant using:
- i. A test procedure listed in 40 CFR 136 which is also approved under A.A.C. R9-14-610;
 - ii. An alternative test procedure approved by EPA as provided in 40 CFR 136 and which is also approved under A.A.C. R9-14-610;
 - iii. A test procedure listed in 40 CFR 136, with modifications allowed by EPA or approved as a method alteration by ADHS under A.A.C. R9-14-610(C); or
 - iv. If no test procedure for a pollutant is available under (3)(b)(i) through (3)(b)(iii) above, any Method approved under A.A.C. R9-14-610(C) for wastewater may be

used, except the use of field kits is not allowed unless otherwise specified in this permit. If there is no approved wastewater method for a parameter, any other method identified in 9 A.A.C. 14, Article 6 that will achieve appropriate detection and reporting limits may be used for analyses.

- c. For results to be considered valid, all analytical work, including those tests conducted by the permittee at the time of sampling (see Part II.A.4.a), shall meet quality control standards specified in the approved methods.
 - d. The permittee shall use analytical methods with a Limit of Quantitation (LOQ) that is lower than the effluent limitations, assessment levels, action levels, or water quality criteria specified in this permit. If all methods have LOQs higher than applicable water quality criteria, the permittee shall use the approved analytical method with the lowest LOQ.
 - e. The permittee shall use a standard calibration curve when applicable to the method, where the lowest standard point is equal to or less than the LOQ.
 - f. If requested, the permittee shall participate in the annual NPDES DMR/QA study and submit the results of this study to ADEQ and ADHS for all laboratories used in monitoring compliance with this permit.
5. Chlorine Monitoring

Because of the short holding time for chlorine, samples may be analyzed on-site using Hach Method No. 10014. Other methods are also acceptable for chlorine if the Method has a LOQ lower than discharge limits specified in this permit.

6. Metals Analyses

In accordance with 40 CFR 122.45(c), all effluent metals concentrations, with the exception of chromium VI, shall be measured as “total recoverable metals”. Discharge limits and assessment levels in this permit are for total metals, except for chromium VI for which the levels listed, if any, are dissolved.

B. Reporting of Monitoring Results

1. The permittee shall report monitoring results on Discharge Monitoring Report (DMR) forms supplied by ADEQ, to the extent that the results may be entered on the forms. The permittee shall submit results of all monitoring required by this permit in a format that will allow direct comparison with the limitations and requirements of this permit. If no discharge occurs during a reporting period, the permittee shall specify “No Discharge” on the DMR. The results of all discharge analyses conducted during the monitoring period shall be included in determinations of the monthly average and daily maximums reported on the DMRs if the analyses were by methods specified in Part II.A above, as applicable.
2. DMRs and attachments are to be submitted (see Appendix A- definitions) by the 28th day of the month following the end of a monitoring period. For example, if the monitoring period ends January 31st, the permittee shall submit the DMR by February 28th. The permittee shall submit

original copies of these and all other reports required in this Part, signed by an authorized representative, to the address or fax number listed below or submit by any other alternative mode as specified by ADEQ.

Arizona Department of Environmental Quality
 Data Unit, Water Quality Compliance Section
 1110 W. Washington St.
 Phoenix, AZ 85007

Or fax to (602) 771-4505.

The permittee shall submit copies of the original lab results (or bench sheets or similar documentation for field parameters) for all parameters monitored during the reporting period with the DMRs.

3. When sampling the effluent for ammonia, the pH and temperature of the receiving water must be recorded at the time of sample collection. Results for all three parameters as well as the applicable ammonia standard and the calculated Ammonia Impact Ratio shall be recorded on the **Ammonia Data Log** provided in Appendix B. The effluent ammonia concentrations, receiving water pH and temperature, and calculated ammonia impact ratio shall also be recorded on DMRs. The ammonia data log shall be submitted to ADEQ annually to the address information listed in Part II.B.2, above.
4. If requested to participate, the permittee shall submit the results of the annual NPDES DMR/QA Study to ADEQ and ADHS for all laboratories used in monitoring compliance with this permit by December 31st of each year. The permittee shall also conduct any proficiency testing required by the NPDES DMR-QA Study for those parameters listed in the study that the permittee analyzes in house or tests in the field at the time of sampling (these parameters may include pH and total residual chlorine). All results of the NPDES DMR-QA Study shall be submitted to address listed below, or submit by any other alternative mode as specified by ADEQ:

Arizona Department of Environmental Quality
 AZPDES Individual Permits Unit, Mailcode: 5415B-3
 1110 W. Washington St.
 Phoenix, AZ 85007

Arizona Department of Health Services
 Attn: Office of Laboratory Licensure and
 Certification
 250 N 17th Avenue
 Phoenix, AZ 85007

5. For the purposes of reporting, the permittee shall use the Limit of Quantitation.
6. For parameters with Daily Maximum Limits or Daily Maximum Assessment Levels in this permit, the permittee shall review the results of all samples collected during the reporting period and report as follows:

For Daily Maximum Limits / Assessment Levels	The Permittee shall Report on the DMR
When the maximum value of any analytical result is greater than or equal to the LOQ	The maximum value of all analytical results
When the maximum value detected is greater than or equal to the laboratory's LOD but less than the LOQ (1)	The numeric result with E4 flag as applicable (AZ qualifier)

For Daily Maximum Limits / Assessment Levels	The Permittee shall Report on the DMR
When the maximum value is less than the laboratory's LOD (2)	"< LOD" with E8 flag as applicable (AZ qualifier) (specify the LOD level, i.e., < 10 ug/L)

Footnotes:

- (1) Not Quantifiable
- (2) Below Detection

7. For parameters with Monthly Average Limits or Monthly Average Assessment Levels in this permit, the permittee shall review the results of all samples collected during the reporting period and report:

For Monthly Average Limits / Assessment Levels		The Permittee shall Report on the DMR
If only one sample is collected during the reporting period (monthly, quarterly, annually, etc.) (In this case, the sample result is the monthly average.)	When the value detected is greater than or equal to the LOQ	The analytical result
	When the value detected is greater than or equal to the laboratory's LOD, but less than the LOQ	The numeric result with E4 flag as applicable (AZ qualifier)
	When the value is less than the laboratory's LOD	"< LOD" with E8 flag as applicable (AZ qualifier) (specify the LOD level, i.e., < 10 ug/L)
If more than one sample is collected during the reporting period	All samples collected in the same calendar month must be averaged. <ul style="list-style-type: none"> • When all results are greater than or equal to the LOQ, all values are averaged • If some results are less than the LOQ, use the LOD value in the averaging • Use '0' for values less than the LOD 	The highest monthly average which occurred during the reporting period

8. For all field testing, or if the information below is not included on the laboratory reports required by Part II.B.2, the permittee shall attach a bench sheet or similar documentation to each DMR that includes, for all analytical results during the reporting period:
- a. the analytical result;
 - b. the number or title of the approved analytical method, preparation and analytical procedure utilized by the field personnel or laboratory, and the LOD and LOQ for the analytical method for the parameter; and
 - c. any applicable data qualifiers using the most current revision of the Arizona Data Qualifiers (available on line at <http://www.azdhs.gov/lab/license/resources/resources.htm>).

C. Twenty-four Hour Reporting of Noncompliance

The permittee shall orally report any noncompliance which may endanger the environment or human health within 24 hours from the time the permittee becomes aware of the event to:

ADEQ 24 hour hotline at (602) 771-2330

The permittee shall include in the written notification: a description of the noncompliance and its cause; the period of noncompliance, including dates and times, and, if the noncompliance has not been corrected, the time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.

D. Monitoring Records

The permittee shall retain records of the following monitoring information:

1. Date, exact location and time of sampling or measurements performed, preservatives used;
2. Individual(s) who performed the sampling or measurements;
3. Date(s) the analyses were performed;
4. Laboratory(s) which performed the analyses;
5. Analytical techniques or methods used;
6. Chain of custody forms;
7. Any comments, case narrative or summary of results produced by the laboratory. These comments should identify and discuss QA/QC analyses performed concurrently during sample analyses and should specify whether analyses met project requirements and 40 CFR 136. If results include information on initial and continuing calibration, surrogate analyses, blanks, duplicates, laboratory control samples, matrix spike and matrix spike duplicate results, sample receipt condition, or holding times and preservation, these records must also be retained.
8. Summary of data interpretation and any corrective action taken by the permittee.

PART III. BIOSOLIDS / SEWAGE SLUDGE REQUIREMENTS

Note: "Biosolids" refers to non-hazardous sewage sludge as defined in 40 CFR 503.9 and Arizona Administrative Code (A.A.C.) R18-9-1001.7. Sewage sludge that is hazardous as defined in 40 CFR 261 must be disposed of in accordance with the Resource Conservation and Recovery Act (RCRA). Sludge with PCB (polychlorinated biphenyls) levels greater than 50 mg/kg must be disposed of in accordance with 40 CFR 761.

A. Use or Disposal Requirements

All biosolids / sewage sludge generated and / or prepared at this facility shall be used or disposed of in compliance with the applicable portions of 18 A.A.C. 9, Article 10 and:

1. 40 CFR 503 Subpart C: for biosolids that are placed on the land (surface disposal) for the purpose of disposal (dedicated land disposal sites, lagoons, or monofills);
2. 40 CFR 258: for biosolids disposed of in municipal solid waste landfills; and
3. 40 CFR 257: for all biosolids use and disposal practices not covered under 40 CFR 258 or 503.

B. Biosolids Preparer's Responsibility

The permittee is responsible for ensuring that all biosolids / sewage sludge produced or accepted at this facility are used or disposed of in accordance with 40 CFR 503 Subpart C, 257, 258 and 18 A.A.C. 9, Article 10, as applicable, whether the permittee uses or disposes of the biosolids itself or transfers them to another party for further treatment, use, or disposal. The permittee is responsible for informing any subsequent transporters, preparers, applicators, and disposers of the requirements that they must meet under 18 A.A.C. 9, Article 10.

C. Duty to Mitigate

The permittee shall take all reasonable steps to prevent or minimize any biosolids use or disposal which has a likelihood of adversely affecting human health or the environment.

D. General Requirements

The permittee shall ensure that:

1. No biosolids generated and / or prepared at this facility enter wetlands or other waters of the United States;
2. Biosolids treatment, storage, use or disposal does not contaminate surface water or groundwater; (*Note: Surface disposal or land treatment sites for biosolids must be permitted under the aquifer protection program per A.A.C. R18-9-1002(E)(2) and may also require a separate AZPDES permit. The permittee shall ensure a site has appropriate permits before directing biosolids to a surface disposal or land treatment site.*)
3. Biosolids treatment, storage, and use or disposal does not create a nuisance such as malodorous smell or attraction of flies or other disease carrying vectors;
4. Biosolids generated and / or prepared at this facility are not applied to the land or placed on a surface disposal site if the biosolids are likely to adversely affect a threatened or endangered species as listed under section 4 of the Endangered Species Act (16 U.S.C 1533), or its designated critical habitat as defined in 16 U.S.C. 1532;
5. Land application sites receiving bulk biosolids generated and / or prepared at this facility are registered with ADEQ in accordance with A.A.C. R18-9-1004; and
6. No biosolids generated and / or prepared at this facility are incinerated in the state of Arizona.

E. Biosolids Storage

1. Biosolids shall not be stored on land for over two years from the time they are generated unless a permit for surface disposal is obtained per 18 A.A.C. 9, Article 10 and 40 CFR 503 Subpart C, or written notification has been submitted to the ADEQ Biosolids Coordinator with the information in 40 CFR 503.20(b) that sufficiently demonstrates the need for longer temporary storage.
2. For the protection of public health, biosolids shall not be stored uncovered on-site or off-site unless the permittee can demonstrate that prior to placement in storage:
 - a. Biosolids meet Class A or B pathogen reduction requirements established in A.A.C. R18-9-1006(D) or (E), and
 - b. Biosolids meet one of the vector attraction reduction alternatives in A.A.C. R18-9-1010 subsections (A)(1) through (A)(8).
 - c. For biosolids which are classified as EQ or Class A, or as Class B through pathogen reduction Alternative 1, the permittee must also sample for pathogen reduction following storage and within 30 days prior to reuse/disposal or distribution (see Part III.J.2.d). Sampling before storage shall occur at least at the minimum frequencies given in Part III.I.1, and sampling after storage shall be conducted as specified in Part III.I.4.
3. Prior to storing biosolids at an off-site storage location, the permittee shall notify the ADEQ Biosolids Coordinator in writing where the biosolids will be stored and the expected date of final use or disposal.

F. Surface Water Protection

The permittee must design and operate all on-site treatment, disposal, or storage areas for biosolids to:

- divert surface run-on from adjacent areas to prevent contact with biosolids;
- protect the site boundaries from erosion; and
- prevent any drainage that has contacted biosolids from escaping the site.

These features shall be designed to be protective for at least a 25-year 24-hour storm event. If the permittee sends biosolids off-site that are not EQB, the permittee shall ensure all treatment, disposal, or storage areas that receive those biosolids have the same level of protection.

G. Facilities with Pretreatment Programs

Permittees with pretreatment programs shall:

1. Sample and analyze biosolids for all the priority pollutants listed under Section 307.a.1 of the Clean Water Act except asbestos. This shall consist of an annual full priority pollutant scan, with quarterly samples analyzed only for those pollutants detected in the full scan.
2. Sample and analyze biosolids quarterly for the following Pollutants of Concern:

Arsenic
Cadmium

Copper
Cyanide

Mercury
Molybdenum

Selenium
Silver

Chromium

Lead

Nickel

Zinc

3. If any biosolids generated and / or prepared at this facility are or will be land applied, the permittee shall design local limits to achieve the ceiling and monthly average pollutant concentration levels for pollutants given in the table at Part III.J.1.a of this permit. If pollutants in the biosolids exceed any of these monthly average pollutant concentration levels, the permittee shall revise its local limits as necessary in order to meet these levels.

H. Inspection and Entry

The permittee shall allow, directly or through contractual arrangements with their biosolids management contractors, authorized representatives of ADEQ and EPA to:

1. Enter upon all premises where biosolids are treated, stored, used, or disposed, either by the permittee or by another party to whom the permittee transfers the biosolids for treatment, storage, use, or disposal;
2. Have access to and copy any records that must be kept under the conditions of this permit and per 18 A.A.C. 9, Article 10 (including those in 40 CFR 503 Subpart C) by the permittee or by another party to whom the permittee transfers the biosolids for further treatment, storage, use, or disposal; and
3. Inspect any facilities, equipment (including monitoring and control equipment), practices, or operations used in biosolids treatment, storage, use, or disposal by the permittee or by another party to whom the permittee transfers the biosolids for treatment, use, or disposal.

I. General Biosolids Monitoring Requirements (dry weight testing)

1. Biosolids Self-monitoring Frequency

Unless otherwise specified in this permit, the permittee shall conduct self-monitoring events at least at the frequency listed in the table that follows for any sampling required in Part III of this permit.

Biosolids Monitoring Frequency

Amount of Biosolids Prepared per Calendar Year (dry metric tons)	Minimum Monitoring Frequency
> 0 to < 290	One sampling event per year
≥ 290 to < 1500	One sampling event per quarter
≥ 1500 to < 15,000	One sampling event per 60 days
≥ 15,000	One sampling event per month

2. Sampling and Analysis Methods

The permittee shall ensure biosolids are tested using the methods specified in 40 CFR 503.8, as required in A.A.C. R18-9-1012(G). Testing shall be performed at a laboratory operating in compliance with A.R.S. 36-495. Because of the potential for re-growth of pathogens, for Class A or EQ biosolids, samples demonstrating pathogen reduction shall be taken within 30 days

before biosolids are shipped off-site, so verification that requirements are met is obtained before the biosolids leave the site.

3. Representative Sampling

The permittee shall ensure that sampling conducted during a monitoring period adequately represents the quality of all biosolids used/treated / disposed over the monitoring period. This may entail taking several samples per sampling event and / or sampling more frequently than the minimum specified.

4. Testing Stockpiled / Accumulated Biosolids Prior to Distribution or Use

If, after treatment, biosolids classified as EQ or Class A, or as Class B demonstrated through Alternative 1, are stockpiled or accumulated on-site prior to reuse / disposal, the permittee shall develop a sampling plan that ensures samples representative of the entire stockpile are collected and analyzed for pathogens within 30 days before distribution or use. The plan shall detail the number and location of samples to be taken from a cross section of **each** pile or area. The plan must include at least 1 sample for each 0-290 metric dry ton increments. More sampling is appropriate when the biosolids are inconsistent in nature or non-uniformly treated.

The permittee must collect and analyze representative samples per the sampling plan. Distribution or use / disposal shall not occur until the permittee verifies that the biosolids sampled meet all applicable requirements for its use / disposal.

5. Testing for Hazardous Waste Determination

The permittee shall test biosolids at least annually, and more frequently as necessary, to determine if biosolids are hazardous in accordance with 40 CFR 261. Initial screening of the biosolids may be conducted by analyzing biosolids for the total amount of a pollutant. This screening test is all that is required each monitoring period if the total amount doesn't exceed the 20X TCLP screening value in the table below. If the total amount of a pollutant exceeds the 20X TCLP screening value, then the leachable amount must be determined using the Toxicity Characteristic Leaching Procedure (TCLP). The disposal of biosolids that test hazardous is not covered under this permit, and all such biosolids must be disposed of in accordance with the Resource Conservation and Recovery Act (RCRA).

Toxicity Characteristic Leaching Procedure Test

Parameter	TCLP Limit mg/L	20 X TCLP Screening Value mg/kg	Minimal Monitoring Frequency per Generator
Metals			
Arsenic	5	100	Once / year
Barium	100	2000	Once / year
Cadmium	1	20	Once / year
Chromium	5	100	Once / year

Lead	5	100	Once / year
Mercury	0.2	4	Once / year
Selenium	1	20	Once / year
Silver	5	100	Once / year
Volatiles and Semi-Volatiles			
Benzene	0.5	10	Once / year
Carbon Tetrachloride	0.5	10	Once / year
Chlorobenzene	100	2000	Once / year
Chloroform	6	120	Once / year
1,2-Dichloroethane	0.5	10	Once / year
1,1-Dichloroethylene	0.7	14	Once / year
Methyl ethyl ketone	200	4000	Once / year
Tetrachloroethylene	0.7	14	Once / year
Trichloroethylene	0.5	10	Once / year
Vinyl Chloride	0.2	4	Once / year
1,4-Dichlorobenzene	7.5	150	Once / year
o-cresol (1)	200	4000	Once / year
m-cresol (1)	200	4000	Once / year
p-cresol (1)	200	4000	Once / year
Cresol (total) (1)	200	4000	Once / year
2,4-Dinitrotoluene	0.13	2.6	Once / year
Hexachlorobenzene	0.13	2.6	Once / year
Hexachlorobutadiene	0.5	10	Once / year
Hexachloroethane	3	60	Once / year
Nitrobenzene	2	40	Once / year
Pentachlorophenol	100	2000	Once / year
Pyridine	5	100	Once / year
2,4,5-Trichlorophenol	400	8000	Once / year
2,4,6-Trichlorophenol	2	40	Once / year
Herbicides / Pesticides			
2,4-D	10	200	Once / year
2,4,5-TP (Silvex)	1	20	Once / year
Chlordane	0.03	0.6	Once / year

Endrin	0.02	0.4	Once / year
Heptachlor	0.008	0.16	Once / year
Heptachlor epoxide	0.008	0.16	Once / year
Lindane	0.44	8.8	Once / year
Methoxychlor	10	200	Once / year
Toxaphene	0.5	10	Once / year

Footnote:

(1) If o-, m-, and p-Cresol concentrations cannot be differentiated, the total cresol (D026) concentration is used. The regulatory level of total cresol is 200 mg/L.

J. Biosolids Limitations and Monitoring Requirements for Land Application

The permittee shall monitor biosolids generated and / or prepared at this facility for land application and limit their use as follows:

1. Metals Concentrations for Land Application

a. Biosolids shall be sampled for the metals listed in the following table at a frequency not less than the minimum indicated for the amount of biosolids prepared annually. Samples shall be taken after all treatment and blending processes, but prior to land application.

Pollutant	Ceiling Concentrations (milligrams/kilogram) (1)	Monthly Average Pollutant Concentrations (milligrams/kilogram) (1)	Minimum Monitoring Frequency per Volume Prepared Annually
Arsenic	75.0	41.0	0 to < 290 dry metric tons – 1 sampling event /year
Cadmium	85.0	39.0	
Chromium	3000.0	Not Applicable	
Copper	4300.0	1500.00	≥ 290 to < 1500 dry metric tons – 1 sampling event /quarter
Lead	840.0	300.00	
Mercury	57.0	17.0	≥ 1500 to < 15,000 dry metric tons – 1 sampling event /60 days
Molybdenum	75.0	Not Applicable	
Nickel	420.0	420.00	≥ 15,000 dry metric tons – 1 sampling event /month
Selenium	100.0	100.0	
Zinc	7500.0	2800.00	

Footnote:

(1) Dry-weight basis

b. The permittee shall not land apply biosolids with pollutant concentrations that exceed any of the ceiling concentrations in the preceding table. The permittee shall not sell or

give away biosolids for land application if pollutant concentrations exceed any of the ceiling concentrations in the preceding table.

- c. If biosolids exceed any Ceiling Concentration in the preceding table, the permittee must:
- Notify the ADEQ Biosolids Coordinator;
 - Find alternative disposal methods other than land application for the biosolids represented by that sampling event; and
 - Identify the source of the pollutants and take appropriate source control measures to reduce the presence of the pollutant(s) of concern.
- d. If biosolids exceed a Monthly Average Pollutant Concentration listed in the table in Part III.I.1.a above:
- The biosolids shall not be applied as bulk biosolids to a lawn or garden.
 - The biosolids shall not be sold or given away if any annual pollutant loading rate listed in Table 3 of A.A.C. R18-9-1005(D) will be exceeded. The annual pollutant loading rate shall be determined using the methodology in 18 A.A.C. 9, Article 10, Appendix A.
 - The biosolids shall not be applied to a site if any cumulative pollutant loading rate in Table 4 of A.A.C. R18-9-1005(D) will be exceeded. The cumulative pollutant loading rate shall be determined using the methodology in A.A.C. R18-9-1005(D).
- e. The permittee shall not apply, sell, or give away biosolids for application to a lawn or garden unless they are Exceptional Quality (EQ) biosolids.
- f. The permittee shall be able to demonstrate that all biosolids meet the definition of EQ biosolids in order to claim exemption from the management practices in A.A.C. R18-9-1007 and R18-9-1008. If claiming biosolids are EQ, during the first two years of EQ biosolids preparation, the permittee shall submit the results of all biosolids testing and details about the pathogen and vector control treatment processes to the ADEQ Biosolids Coordinator. The permittee shall receive written confirmation from ADEQ that the results demonstrate the biosolids meet EQ requirements prior to selling or giving away or land applying any biosolids for uses requiring an EQ biosolids classification.

2. **Pathogen Reduction Requirements for Land Application**

- a. Biosolids must meet Class A or Class B pathogen reduction requirements established in A.A.C. R18-9-1006 at the time the biosolids are land applied and, if stored uncovered prior to land application, at the time the biosolids are stored. The permittee shall also verify that the reduction is met within 30 days prior to distribution (see Part III.I.4). The permittee shall document and retain records of the treatment used to achieve Class A or Class B pathogen reduction levels and, if demonstrating treatment to Class A, the fecal

coliform or *Salmonella sp.* density. Retesting is required within 30 days of distribution for EQ and Class A biosolids and for Class B biosolids if pathogen reduction was demonstrated through Alternative 1.

- b. Biosolids sold or given away in a bag or other container for land application, or applied on a lawn or home garden, shall meet the Class A pathogen reduction requirements established in A.A.C. R18-9-1006(D).
- c. The permittee shall maintain daily records of the operating parameters for the pathogen reduction treatment alternative used. If using A.A.C. R18-9-1006(D) Alternative 4, the permittee shall demonstrate acceptable levels of enteric virus and viable helminth ova through monitoring.
- d. Microbiological monitoring for fecal coliforms or *Salmonella sp.* to demonstrate pathogen reduction during a given monitoring period shall be conducted as close to the actual distribution or disposal of the biosolids as feasible. The analytical results must demonstrate effective pathogen reduction is achieved prior to distributing or disposing of the biosolids. If the permittee stores biosolids before they are distributed for use or disposal, microbiological testing must take place within 30 days prior to distribution or disposal.
- e. In order to demonstrate Class B pathogen reduction using A.A.C. R18-9-1006(E) Alternative 1:
 - At least seven individual grab samples must be taken and analyzed for fecal coliform during each monitoring event (unless an alternate sampling plan has been approved by ADEQ).
 - The geometric mean of the results must be <2,000,000 MPN/gram or CFU/gram of total solids (dry-weight basis).
 - Samples are to be taken over a 14-day period to adequately represent sludge variability.

(Note: A 'monitoring event' includes the period of time that samples are collected, analyzed, and the sample results provided to the permittee.)
- f. In order to demonstrate Class A pathogen reduction, in addition to meeting one of the alternative pathogen treatment options in A.A.C. R18-9-1006(D):
 - At least seven individual grab samples must be collected and analyzed for fecal coliform during each monitoring event (unless an alternate sampling plan has been approved by ADEQ) and all seven samples must be < 1,000 MPN/gram; or
 - At least seven individual grab samples must be collected and analyzed for *Salmonella sp.* during each monitoring event (unless an alternate sampling plan has been approved by ADEQ) and each must be <3 MPN/4 grams total solids (dry-weight basis).
 - Samples are to be taken over a 14-day period to adequately represent sludge variability.
- g. If demonstrating Class A pathogen reduction using A.A.C. R18-9-1006(D) Alternative 4:

- One composite sample consisting of at least seven grab samples must be collected and analyzed for enteric virus during each monitoring event and the arithmetic mean of 4 duplicate analyses of that composite must be < 1 PFU/ 4 grams total solids (dry-weight basis). Grab samples are to be taken over a 14-day period prior to compositing them to adequately represent sludge variability, and the maximum holding time is 2 weeks.
- One composite sample consisting of at least seven grab samples must be collected and analyzed for viable helminth ova during each monitoring event and the arithmetic mean of 4 duplicate analyses of that composite must be < 1 viable ova/ 4 grams total solids (dry-weight basis). Grab samples are to be taken over a 14-day period prior to compositing them to adequately represent sludge variability.

3. **Vector Attraction Reduction Requirements for Land Application**

- a. The permittee shall ensure that all biosolids generated and / or prepared at this facility meet the vector attraction reduction requirements established in A.A.C. R18-9-1010 when the biosolids are land-applied. If biosolids are stored uncovered prior to land application, one of the vector attraction reduction alternatives established in A.A.C. R18-9-1010 subsections (A)(1) through (A)(8) must be met prior to storage. The permittee shall document and retain records of the operational parameters or application methods used to achieve the vector attraction reduction requirements.
- b. The permittee shall ensure that all biosolids generated and / or prepared at this facility that are sold or given away in a bag or other container, or applied to a lawn or home garden, meet one of the vector attraction reduction alternatives established in A.A.C. R18-9-1010 subsections (A)(1) through (A)(8). The permittee shall document and retain records of the operational parameters or application methods used to achieve the vector attraction reduction requirements.

4. **Nitrogen Testing for Land Application**

The permittee shall ensure that biosolids generated and / or prepared at this facility for land application are tested for organic-N, ammonium-N, and nitrate-N at least at the applicable minimum frequency in Part III.I and that the most recent test results are provided to any subsequent preparer, user, or disposer.

K. Management Practices for Land Application

The permittee shall ensure that all non-EQ bulk biosolids generated and / or prepared at this facility are land applied in accordance with the management practices in A.A.C. R18-9-1007, unless the bulk biosolids are land applied for reclamation.

If the permittee generates or prepares non-EQ bulk biosolids that are land applied for reclamation, the permittee shall ensure that the biosolids are land applied in accordance with the management practices in A.A.C. R18-9-1008.

If the permittee generates or prepares non-EQ biosolids placed in a bag or other container for distribution / land application or reclamation, the permittee shall distribute a label or information sheet to the person receiving the material. This label or information sheet shall contain the information in A.A.C. R18-9-1007(B).

L. Biosolids / Sewage Sludge Limitations and Monitoring Requirements for Surface Disposal

The permittee shall ensure that any sewage sludge or biosolids directed to or placed in a surface disposal unit meets the requirements of 40 CFR 503 Subpart C. The permittee shall also ensure the surface disposal site is permitted under the aquifer protection program and has a valid AZPDES permit prior to disposal of any biosolids in the unit.

M. Biosolids Monitoring Requirements for Disposal in a Municipal Landfill

Biosolids placed in a municipal landfill shall be tested by the Paint Filter Test (method 9095) at the frequency in Part III.J.1 above or more often as necessary to demonstrate that there are no free liquids. The permittee shall keep records documenting that biosolids disposed in a municipal landfill did not contain free liquids.

N. On-site Management Plan

The permittee shall submit a Management Plan (Plan) within 180 days of permit issuance or maintain a previously submitted Plan for the on-site management operations.

This Plan shall detail how sludge/biosolids are managed from the time that they are generated at the facility until they are shipped off-site. The Plan shall give specific protocols to be followed to ensure that the material generated at this facility will consistently meet all applicable requirements in 18 A.A.C. 9, Article 10 and 40 CFR Part 503 Subpart C and the provisions of this permit. The Plan must address issues of potential concern such as storage areas; run-on and run-off control; odor and dust control; and include a professional diagram of facilities / areas used in the operation and the area surrounding the operation. The Plan shall specify how and when representative samples of biosolids will be taken and contain a contingency plan for managing biosolids that exceed the requirements for the expected end use / disposal.

O. Record Keeping

1. The permittee shall collect and retain all biosolids information required by this permit and A.A.C. R18-9-1013(A)(1) through (A)(6) for at least five years.
2. The permittee shall keep analytical test results and all documentation that supports the biosolids classification on-site and available for review.
3. All biosolid records are subject to periodic inspection, and copying by ADEQ.

P. Notification Requirements

The permittee, either directly or through contractual arrangements with their biosolids management contractors, shall comply with the following:

1. Notification of Noncompliance

- a. The permittee shall notify ADEQ of any noncompliance with the biosolids provisions of this permit or with 18 A.A.C. 9, Article 10, which may endanger health or the environment. The permittee shall provide the information orally within 24 hours from the time the permittee becomes aware of the circumstances (See Part II.C of this permit.)
- b. For other instances of noncompliance with the biosolids provisions, the permittee shall notify the ADEQ Biosolids Coordinator in writing within five working days of becoming aware of the circumstances.
- c. Permittees shall require their biosolids management contractors to notify ADEQ of any noncompliance within the time-frames specified in Sections P.1.a and b.

2. Notification of Shipment to another State

If biosolids are shipped to another State or to Indian Lands, the permittee shall send a notice of the shipment to the NPDES permitting authorities in the receiving State or Indian Land (the EPA Regional Office for that area and the State/Indian authorities) with a copy to the Arizona Biosolids Coordinator. The notice shall be sent at least 60 days before the biosolids are planned to be shipped.

3. Notification of Change in Land Application Sites, Applicators, or Disposal Methods

- a. Prior to sending, placing or applying any bulk biosolids generated and / or prepared at this facility to a site that the permittee has not previously utilized for biosolids use / disposal within the last five years, the permittee must verify that the application site has been registered in accordance with A.A.C. R18-9-1004 and shall notify the ADEQ Biosolids Coordinator of the planned change. The notification shall include a description and topographic map of the proposed site(s), latitude and longitude coordinates at the center of each field / site, slope of land surface, names and addresses of the applicator(s) and site owner(s), a listing of any state or local permits which must be obtained, a description of the crops or vegetation to be grown at each site, proposed loading rates and determination of agronomic rates.
- b. Prior to selling or giving away bulk biosolids for land application to an applicator that the permittee has not sold or given biosolids to within the last five years, the permittee shall notify the ADEQ Biosolids Coordinator of the planned change. The notification shall include: the name, address, and telephone number of the applicator and any agent of the applicator; the name and telephone number of a primary contact person who has specific knowledge of the land application activities of the applicator; and whether the applicator holds a NPDES or AZPDES permit, and, if so, the permit number.
- c. Prior to changing the method of biosolids use, treatment or disposal that was identified in the permittee's application for this permit, the permittee shall notify the ADEQ Biosolids Coordinator of the planned change in writing. If ADEQ determines that the newly proposed practice is not covered under this permit, the permittee shall request and receive a permit modification prior to making the change.

- d. The permittee shall keep records of site registration verifications and of all notifications made to ADEQ.

4. Notification of Land Application of Biosolids that Exceed Monthly Average Pollutant Concentrations

The permittee must notify the ADEQ Biosolids Coordinator and any subsequent biosolids handlers if biosolids generated and / or prepared at this facility do not meet any of the Monthly Average Pollutant Concentration values listed at Part III.J.1.a above. The permittee shall ensure that bulk biosolids exceeding a monthly average pollutant concentration will not be applied to a site if any cumulative pollutant loading rate (Table 4 in A.A.C. R18-9-1005) will be exceeded per A.A.C. R18-9-1005(D)(2).

5. Notification to Subsequent Land Applicators

The permittee shall notify the applicator of all the applicator's requirements under Title 18 Chapter 9 Article 10 including the requirement that the applicator certify that management practices, site restrictions, and any applicable vector attraction reduction requirements have been met.

6. Notification of Surface Disposal

Prior to disposal in a new or previously unreported surface disposal site, the permittee shall notify the Biosolids Coordinator in writing. Notice shall include a description and a topographic map of the proposed site; the names of the site operator and site owner; whether the site has any permits; and shall include a description of procedures for ensuring public access and grazing restrictions until three years following site closure. The permittee shall not direct biosolids to the surface disposal site without prior written approval from ADEQ.

Q. Annual Report for All Permittees

The permittee shall submit an annual biosolids report to ADEQ by **February 19 of each year** for the period covering the previous calendar year. The report shall be filled out on forms prescribed by ADEQ and shall include:

1. The amount of biosolids received / generated the previous calendar year and the amount stored at the beginning and end of the previous calendar year, in dry tons or dry metric tons (prefer metric tons), and the amount distributed.
2. The results of all biosolids analytical monitoring conducted during the previous calendar year and copies of the laboratory analytical reports. Metals (other than TCLP metals) shall be reported on a 100% dry weight basis. Note: Make certain microbiological testing submitted meets required holding times.
3. Descriptions of pathogen reduction methods and vector attraction reduction methods used during the previous calendar year. The permittee must submit sludge processing data used to demonstrate how treatment alternative(s) in A.A.C. R18-9-1006 and R18-9-1010 were attained, (such as time, temperature, percent solids, pH etc.) as applicable.

4. Names, mailing addresses, and street addresses of all persons who received biosolids generated and / or prepared at this facility for storage, further treatment, disposal in a municipal waste landfill, or for other use / disposal methods not covered under 40 CFR 258 or 503, and the amount delivered to each.
5. Except for biosolids that are demonstrated to be EQ, the following information shall be submitted by the permittee for land application sites, unless the permittee requires its biosolids management contractors to report this information directly to ADEQ:
 - a. Locations of land application sites (with field names and numbers) used that calendar year, size of each field applied to, applicer, and site owner;
 - b. Volumes applied to each field (in wet tons and dry metric tons), nitrogen applied, calculated plant available nitrogen;
 - c. Crop(s) planted, date of planting, harvesting;
 - d. For any biosolids exceeding A.A.C. R18-9-1005 Table 2 metals concentrations, the locations of sites where applied and cumulative metals loading at each of these sites to date;
 - e. Certifications of management practices in A.A.C. R18-9-1007 or A.A.C. R18-9-1008; and
 - f. Certifications of site restrictions in A.A.C. R18-9-1009.
6. For surface disposal sites, the permittee shall ensure that the following information is submitted, the permittee requires its biosolids management contractors to report this information directly to ADEQ:
 - a. Locations of sites, site operator, site owner, size of parcel on which disposed;
 - b. Results of any required groundwater monitoring;
 - c. A description of and certifications of management practices in 40 CFR 503.24; and
 - d. For closed sites, date of site closure and certifications of management practices for the three years following site closure.

R. Reporting Location

The annual report shall be submitted to the address listed below, or by an alternative mode of submittal specified by ADEQ.

ADEQ Biosolids Coordinator
Water Quality Compliance Section
1110 W. Washington St.
Phoenix, AZ 85007
602-771-7674

PART IV. WHOLE EFFLUENT TOXICITY TESTING REQUIREMENTS

Not required.

PART V. SPECIAL CONDITIONS

A. OPERATION

The permittee shall ensure that the facilities or systems are operated by or under the supervision of an operator currently certified by ADEQ at the level appropriate for the facility or system.

B. REOPENER

This permit may be modified per the provisions of A.A.C. R18-9-B906, and R18-9-A905 which incorporates 40 CFR Part 122. This permit may be reopened based on newly available information; to add conditions or limits to address demonstrated effluent toxicity; to implement any EPA-approved new Arizona water quality standard; or to re-evaluate reasonable potential (RP), if assessment levels in this permit are exceeded.

APPENDIX A PART A: ACRONYMS

A.A.C.	Arizona Administrative Code
ADEQ	Arizona Department of Environmental Quality
ADHS	Arizona Department of Health Services
EQ	Exceptional Quality (biosolids)
AZPDES	Arizona Pollutant Discharge Elimination System
A.R.S.	Arizona Revised Statutes
CFR	Code of Federal Regulations
CFU	Colony Forming Units
Director	The Director of ADEQ or any authorized representative thereof
DMR	Discharge Monitoring Report
EPA	The U.S. Environmental Protection Agency
kg/day	kilograms per day
MGD	Million Gallons per Day
mg/L	milligrams per Liter, also equal to parts per million (ppm)
MPN	Most Probable Number
NPDES	National Pollutant Discharge Elimination System
PFU	Plaque-Forming Unit
QA	Quality Assurance
SSU	Sewage Sludge Unit
TBEL	Technology-based effluent limitation
ug/L	micrograms per Liter, also equal to parts per billion (ppb)
WQBEL	Water quality-based effluent limitation

APPENDIX A PART B: DEFINITIONS

ACTIVE SEWAGE SLUDGE UNIT means a sewage sludge unit that has not closed.

AGRONOMIC RATE means the whole biosolids application rate on a dry-weight basis that meets the following conditions:

- a.) The amount of nitrogen needed by existing vegetation or a planned or actual crop has been provided, and
- b.) The amount of nitrogen that passes below the root zone of the crop or vegetation is minimized.

ANNUAL POLLUTANT LOADING RATE means the maximum amount of a pollutant that can be applied to an acre or hectare of land during a 365-day period.

APPLICATOR means a person who arranges for and controls the site-specific land application of biosolids in Arizona.

BASE FLOOD means a flood that has a one percent chance of occurring in any given year (or a flood that is likely to occur once in 100 years).

BULK BIOSOLIDS means biosolids that are transported and land-applied in a manner other than in a bag or other container holding biosolids of 1.102 short tons or 1 metric ton or less.

COMPOSITE SAMPLE means a sample that is formed by combining a series of individual, discrete samples of specific volumes at specified intervals. Composite samples characterize the quality of a discharge over a given period of time. Although, composite samples can be time-weighted or flow-weighted, this permit requires the collection of flow-proportional composite samples. This means that samples are collected and combined using aliquots in proportion to flow rather than time. Also see Flow-Proportional Composite.

CUMULATIVE POLLUTANT LOADING RATE means the maximum amount of a pollutant applied to land application site.

DAILY MAXIMUM CONCENTRATION LIMIT means the maximum allowable discharge of a pollutant in a calendar day as measured on any single discrete sample or composite sample.

DAILY MAXIMUM MASS LIMIT means the maximum allowable total mass of a pollutant discharged in a calendar day.

DISCRETE or GRAB SAMPLE means an individual **sample of at least 100 mL** collected from a single location or over a period of time not exceeding 15 minutes.

DRY-WEIGHT BASIS means the weight of biosolids calculated after the material has been dried at 105 °C until reaching a constant mass.

EXCEPTIONAL QUALITY BIOSOLIDS means biosolids certified under R18-9-1013(A)(6) as meeting the pollutant concentrations in R18-9-1005 Table 2, Class A pathogen reduction in R18-9-1006, and one of the vector attraction reduction requirements in subsections R-18-9-1010(A)(1) through R18-9-1010(A)(8).

FLOW PROPORTIONAL COMPOSITE SAMPLE means a sample that combines discrete samples collected over time, based on the flow of the discharge being sampled. There are two methods used to collect this type of sample. One collects a constant sample volume at time intervals that vary based on stream flow. The other collects discrete samples that are proportioned into aliquots of varying volumes based on stream flow, at constant time intervals (i.e. flow-weighted composite sample).

LAND APPLICATION or LAND APPLY means spraying or spreading biosolids on the surface of the land, injecting biosolids below the land's surface, or incorporating biosolids into the soil to amend, condition, or fertilize the soil.

LAND TREATMENT FACILITY means an operation designed to treat and improve the quality of waste, wastewater, or both, by placement wholly or in part on the land surface to perform part or all of the treatment. A land treatment facility includes a facility that performs biosolids drying, processing, or composting, but not land application performed in compliance with 18 A.A.C. 9, Article 10.

LIMIT OF QUANTITATION (LOQ) means the minimum levels, concentrations, or quantities of a target variable such as an analyte that can be reported with a specific degree of confidence. The calibration point shall be at or below the LOQ. The LOQ is the concentration in a sample that is equivalent to the concentration of the lowest calibration standard analyzed by a specific analytical procedure, assuming that all of the method-specified sample weights, volumes, and processing steps have been followed.

LIMIT OF DETECTION (LOD) means an analyte and matrix-specific estimate of the minimum amount of a substance that the analytical process can reliably detect with a 99% confidence level. This may be laboratory dependent and is developed according to R9014-615(C)(7).

METHOD DETECTION LIMIT (MDL) - See LOD.

MIXING ZONE is an area where an effluent discharge undergoes initial dilution and may be extended to cover the secondary mixing in the ambient waterbody. A mixing zone is an allocated impact zone where water quality criteria can be exceeded as long as acutely toxic conditions are prevented.

MONTHLY OR WEEKLY AVERAGE CONCENTRATION LIMIT, other than for bacteriological testing, means the highest allowable average calculated as an arithmetic mean of consecutive measurements made during calendar month or week, respectively. The "monthly or weekly average concentration limit" for *E. coli* bacteria means the highest allowable average calculated as the geometric mean of a minimum of four (4) measurements made during a calendar month or week, respectively. The geometric mean is the n th root of the product of n numbers. For either method (CFU or MPN), when data are reported as "0" or non-detect then input a "1" into the calculation for the geometric mean.

MONTHLY OR WEEKLY AVERAGE MASS LIMITATION means the highest allowable value that shall be obtained by taking the total mass discharged during a calendar month or week, respectively, divided by the number of days in the period that the facility was discharging. Where less than daily sampling is required by this permit, the monthly or weekly average value shall be determined by the summation of all the measured discharges by mass divided by the number of days during the month or week, respectively, when the measurements were made.

PATHOGEN means a disease-causing organism.

RUNOFF means rainwater, leachate, or other liquid that drains over any part of a land surface and runs off of the land surface.

SEWAGE SLUDGE UNIT means land on which only sewage sludge is placed for final disposal. This does not include land on which sewage sludge is either stored or treated. Land does not include navigable waters.

SIGNIFICANT DIFFERENCE is defined as statistically significant difference (e.g., 95% confidence level) in the means of two distributions of sampling results.

STORE BIOSOLIDS or STORAGE OF BIOSOLIDS means the temporary holding or placement of biosolids on land before land application.

SURFACE DISPOSAL SITE means an area of land that contains one or more active sewage sludge units.

SUBMIT, as used in this permit, means post-marked, documented by other mailing receipt, or hand-delivered to ADEQ.

TON means a net weight of 2000 pounds and is known as a short ton.

TOTAL SOLIDS means the biosolids material that remains when sewage sludge is dried at 103° C to 105° C.

VECTORS means rodents, flies, mosquitoes, or other organisms capable of transporting pathogens.

APPENDIX B – AMMONIA SPECIAL REPORTING REQUIREMENTS

The Arizona Administrative Code, Title 18, Chapter 11 Department of Environmental Quality Water Quality Standards contains acute and chronic ammonia standards that are contingent upon temperature and/or pH values. The chronic criteria are more stringent than the acute ammonia criteria, so the effluent ammonia will be compared to the chronic ammonia standards. The chronic table for Aquatic and Wildlife warm follows below. The permittee may refer to these tables to determine the ammonia standard that applies each time an ammonia sample is taken. The permittee must record all data results for ammonia, pH, temperature and sampling dates in the Ammonia Data Log. The required minimum sampling frequency for these parameters may be found in Table 1 of this permit. Anytime an ammonia sample is found to be above the corresponding ammonia standard for the pH and temperature at the time the sample was taken, the permittee must highlight this on the ammonia data log. These results must also be reported on DMRs with any exceedances noted. Annual submittal of the ammonia data log is required (See Part II.B.3).

A&W Designated Uses

Determination of Chronic Total Ammonia Criteria as N in mg / L										
Based on pH and Temperature at Time of Sampling (1) (2)										
pH	Temperature, °C									
	0	14	16	18	20	22	24	26	28	30
6.5	6.67	6.67	6.06	5.33	4.68	4.12	3.62	3.18	2.80	2.46
6.6	6.57	6.57	5.97	5.25	4.61	4.05	3.56	3.13	2.75	2.42
6.7	6.44	6.44	5.86	5.15	4.52	3.98	3.5	3.07	2.7	2.37
6.8	6.29	6.29	5.72	5.03	4.42	3.89	3.42	3	2.64	2.32
6.9	6.12	6.12	5.56	4.89	4.3	3.78	3.32	2.92	2.57	2.25
7	5.91	5.91	5.37	4.72	4.15	3.65	3.21	2.82	2.48	2.18
7.1	5.67	5.67	5.15	4.53	3.98	3.5	3.08	2.7	2.38	2.09
7.2	5.39	5.39	4.9	4.31	3.78	3.33	2.92	2.57	2.26	1.99
7.3	5.08	5.08	4.61	4.06	3.57	3.13	2.76	2.42	2.13	1.87
7.4	4.73	4.73	4.3	3.78	3.33	2.92	2.57	2.26	1.98	1.74
7.5	4.36	4.36	3.97	3.49	3.06	2.69	2.37	2.08	1.83	1.61
7.6	3.98	3.98	3.61	3.18	2.79	2.45	2.16	1.9	1.67	1.47
7.7	3.58	3.58	3.25	2.86	2.51	2.21	1.94	1.71	1.5	1.32
7.8	3.18	3.18	2.89	2.54	2.23	1.96	1.73	1.52	1.33	1.17
7.9	2.8	2.8	2.54	2.24	1.96	1.73	1.52	1.33	1.17	1.03
8.0	2.43	2.43	2.21	1.94	1.71	1.50	1.32	1.16	1.02	0.897

<u>Determination of Chronic Total Ammonia Criteria as N in mg / L</u>										
<u>Based on pH and Temperature at Time of Sampling (1) (2)</u>										
8.1	2.1	2.1	1.91	1.68	1.47	1.29	1.14	1.00	0.879	0.773
8.2	1.79	1.79	1.63	1.43	1.26	1.11	0.973	0.855	0.752	0.661
8.3	1.52	1.52	1.39	1.22	1.07	0.941	0.827	0.727	0.639	0.562
8.4	1.29	1.29	1.17	1.03	0.906	0.796	0.7	0.615	0.541	0.475
8.5	1.09	1.09	0.99	0.87	0.765	0.672	0.591	0.52	0.457	0.401
8.6	0.92	0.92	0.836	0.735	0.646	0.568	0.499	0.439	0.386	0.339
8.7	0.778	0.778	0.707	0.622	0.547	0.48	0.422	0.371	0.326	0.287
8.8	0.661	0.661	0.601	0.528	0.464	0.408	0.359	0.315	0.277	0.244
8.9	0.565	0.565	0.513	0.451	0.397	0.349	0.306	0.269	0.237	0.208
9	0.486	0.486	0.442	0.389	0.342	0.3	0.264	0.232	0.204	0.179

Footnotes:

- (1) pH and temperature are field measurements taken at the same time and location as the water samples destined for the laboratory analysis of ammonia.
- (2) If field measured pH and/or temperature values fall between the Chronic Total Ammonia tabular values, round field measured values according to standard scientific rounding procedures to nearest tabular value to determine the ammonia standard.